

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 2045 Morse Road

1001449

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6787

WELL LOCATION

CONSTRUCTION DETAILS

County Ashtabula Township Harts Grove

Owner/Builder Bryan Throat
Address of Well Location 4649 Laskey Rd
City Rome Zip Code 44085
Permit No. 90 Section/lot No. (Block One of Four)

Location of Well in State Plane coordinates, if available.
N X 805 ft. or m.
S Y 805 ft. or m.
Elevation of Well 805
Datum: Plain NAD27 NAD83 Elevation Source GPS
Source of Coordinates: GPS Survey Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here. Lat. 41° 17' 12.2" N Long. 80° 35' 16.5" W



Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other ☐

BOREHOLE/CASING (measured from ground surface)
1 Borehole Diameter 10 inches Depth 25 ft.
Casing Diameter 6 1/4 inches Length 26-4 ft. Thickness 5DR24
2 Borehole Diameter 6 1/4 inches Depth 60 ft.
Casing Diameter 6 5/8 inches Length 26-4 ft. Thickness 5DR24
Casing Height Above Ground 1-4 ft.

Type 1 Steel 1 Galv. 1 PVC 1 Other
2 Steel 2 Galv. 2 PVC 2 Other

Joints 1 Threaded 1 Welded 1 Solvent 1 Other
2 Threaded 2 Welded 2 Solvent 2 Other

SCREEN
Diameter 6 5/8 Slot Size 50 Screen Length 3 ft.
Type Slotted Material PVC
Set Between 22 ft. and 25 ft.

GRAVEL PACK (Fill Pack)
Material/Size 1/4 x 1/2 silica Volume/Weight Used 150
Method of Installation oversize / gravity pour
Depth: Placed FROM 25 ft. TO 15 ft.

GROUT
Material Best Seal Volume/Weight Used 150
Method of Installation oversize / gravity pour
Depth: Placed FROM 15 ft. TO surface ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc. From To

yellow clay 0 7
gray shale soft formed 7 23
WBC 72-73
grayish white shale (hard) 23 60

WELL TEST*

Pre-Pumping Static Level 8 ft. Date 11/12/07
Measured from: Top of Casing ☒ Ground Level ☐ Other ☐
Air ☒ Bailing ☐ Pumping ☐ Other ☐
Test Rate 8 gpm Duration of Test 2 hrs.
Feet of Drawdown 53 Sustainable Yield 7 gpm
(Attach a copy of the pumping test record, per section 1521.05, OHC)
Is Copy Attached? Yes No Flowing Well? Yes No
Quality clear

PUMP/PITLESS

Type of pump Subm Capacity 10 gpm
Pump set at 55 Pitless Type Well Through
Pump installed by Curvins Farm Well Dr.
I hereby certify the information given is accurate and correct to the best of my knowledge.
Drilling Firm Curvins Farm Well Dr.
Address 5455 Rt 334
City/State/Zip Rome, OH 44085
Signed A. R. G. W. Date 12/5/07
ODH Registration Number 850

(If more space is needed to complete drilling log, use next consecutively numbered form.)
Date of Well Completion 11/12/07 Total Depth of Well 60 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy