

WELL LOCATION

CONSTRUCTION DETAILS


County LAKE Township MADISON
Owner/Builder TERRY PAULA DINE
Address of Well Location 3955 Bates Rd
City MADISON OH Zip Code 44057
Permit No. 2007318464 Section/Lot No. 10/200 (See City or State)
Location of Well in State Plane coordinates, if available: Use of Well Buildg
N X S Y
Elevation of Well 747
Datum Plane: NAD27 NAD83 Elevation Source GPS
Source of Coordinates: GPS Survey Other

Notary / Cable / Argonand / Driven / Other /
BOREHOLE/CASING (Measurements from ground surface)
1. Borehole Diameter 6.75 inches Depth 22 ft.
Casing Diameter 6.75 inches Length 24 ft. Thickness 50 in.
2. Borehole Diameter inches Depth ft.
Casing Diameter inches Length ft. Thickness in.
Casing Height Above Ground 2 ft.
Type Steel Galv. PVC Other
Joints 1 Threaded 2 Welded 1 Solvent 2 Other

SCREEN
Diameter 6.75 Slot Size .050 Screen Length 2 ft.
Type Slotted Material PVC
Set Between 21 ft. and 23 ft.

GRAVEL PACK (Filter Pack)
Material/Size 4x6 silica Volume/Weight Used 100#
Method of Installation OVER 5122 / CLARKY POLY
Depth: Placed FROM 18 ft. TO 53 ft.
GROUT
Material Beniseal Volume/Weight Used 300#
Method of Installation OVER 5122 / CLARKY POLY
Depth: Placed FROM 18 ft. TO SURFACE ft.

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 41 46322 Long: 81 01640
North:



DRILLING LOG
INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc. From To
yellow clay 0 to 12
gray shale soft hard 12 to 53
water bearing (19-21)

WELL TEST

Pre-Pumping Static Level 3 ft. Date 12 07 07
Measured from: Top of Casing 2 ft. Ground Level Other
 Air Sealing Pumping Other
Test Rate 36 gpm Duration of Test 4 hrs.
Feet of Drawdown 55 ft. Sustainable Yield 3 gpm
(Attach a copy of the pumping test record, per section 1521.05, O.R.C.)
Is Copy Attached? Yes No Flowing Well? Yes No
Quality clear / some odor

PUMP/PITLESS

Type of pump Super Capacity 10 gpm
Pump set at 45 ft. Pitless Type Full Thread by
Pump installed by CLARKY POLY
I hereby certify the information given is accurate and correct to the best of my knowledge.
Drilling Firm CLARKY POLY
Address 5425 St. Rt 534
City, State, Zip Home, OH 44085
Signed ALY Date 12 14 07
ODNR Registration Number N 850

If more space is needed to complete drilling log, use next consecutively numbered form.
Date of Well Completion 12 07 07 Total Depth of Well 58 ft.