

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD


Ohio Department of Natural Resources
Division of Water, 2045 Morse Road
Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1001473

WELL LOCATION

County LAKE Township LEROY
Owner/Builder MICHAEL STEPHENS
Address of Well Location 12459 PINECONE LANE
City AINESVILLE Zip Code 44077
Permit No. 2007328449 State/Lot No. 44077
Location of Well in State Plane coordinates, if available: U.S.A. of Well SINGLE FAMILY
N X + - ft. or m
S Y + - ft. or m
Elevation of Well 866 ft. or m
Datum Plane: NAD27 NAD83 Elevation Source GPS
Source of Coordinates: GPS Survey Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here. 41.41532 N 81.1146 W



CONSTRUCTION DETAILS

Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other ☐
BOREHOLE/CASING (Measured from ground surface)
1 Borehole Diameter 10 1/2 inches Depth 18' 60" ft.
Casing Diameter 6 inches Length 244 ft. Thickness 188 in.
2 Borehole Diameter inches Depth ft.
Casing Diameter in. Length ft. Thickness in.
Casing Height Above Ground 60 ft.
Type 1 2 Steel 1 2 Galv. 1 2 PVC 1 2 Other
Joints 1 2 Threaded 2 2 Welded 2 2 Solvent 2 2 Other
SCREEN
Diameter N/A Slot Size Screen Length ft.
Type Material
Set Between ft. and ft.
GRAVEL PACK (Filter Pack)
Material/Size N/A Volume/Weight Used
Method of Installation
Depth: Placed FROM ft. TO ft.
GROUT
Material Concrete Volume/Weight Used 300 #
Method of Installation orange gravity pour
Depth: Placed FROM 18' ft. TO SURFACE ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc. From To
Yellow Gray Hardpan 0 14
Gray shale Med to soft 14 60

Water bearing 22' 26'

South

WELL TEST*

Pre-Pumping Static Level 14 ft. Date 7/25/07
Measured from: Top of Casing ☒ Ground Level ☐ Other ☐
☐ Air ☒ Bailing ☐ Pumping ☐ Other ☐
Test Rate 4 gpm Duration of Test 3 1/2 hrs.
Feet of Drawdown 60 ft. Sustainable Yield 3 1/2 gpm
(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☒ Yes ☐ No Flowing Well? ☐ Yes ☒ No
Quality Clear

PUMP/PITLESS

Type of pump Capacity gpm
Pump set at ft. Pitless Type
Pump installed by
I hereby certify the information given is accurate and correct to the best of my knowledge.
Drilling Firm Guarantee Home Water Drilling
Address 5855 S.W. 5th St
City, State, Zip Home, OH 44085
Signed [Signature] Date 7/26/07
ODNR Registration Number 850

*If more space is needed to complete drilling log, use next consecutively numbered form.
Date of Well Completion 7/26/07 Total Depth of Well 60 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy