

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 2045 Morse Road
Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1003375

WELL LOCATION

County COSHOCTON Township CHAMFORD

Owner/Builder DAVID C. HABER
(Circle One or Both) First Last

Address of Well Location 33284 CO. RD. 12
Number Street Name

City BALTIC Zip Code +4 43804

Permit No. 379,044 Section/Lot No. _____
(Circle One or Both)

Location of Well in State Plane coordinates, if available:

Use of Well RESIDENTIAL

N ☐ X ☐ +/- _____ ft. or m

S ☐ Y ☐ +/- _____ ft. or m


Elevation of Well +/- _____ ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____
North

N 40° 26,385
W 081° 48,254



WELL TEST*

Pre-Pumping Static Level 60 ft. Date 7-1-08

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other _____

☐ Air ☒ Bailing ☐ Pumping* ☐ Other _____

Test Rate 15T gpm Duration of Test 4 hrs.

Feet of Drawdown 10 ft. Sustainable Yield 15T gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No

Quality 6-HARD/1.0 IRON/6.4 PH.

PUMP/PITLESS

Type of pump AIA Capacity _____ gpm

Pump set at _____ ft. Pitless Type _____

Pump installed by OWNER

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm WILLIAM FAIT DRILLING

Address 4165 BOYSCOUT RD.

City, State, Zip DOVER OH.

Signed William Fait Date 7-19-08

ODH Registration Number 02395

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other _____

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 10 inches Depth 38' ft.

Casing Diameter 5 in. Length 60' ft. Thickness 0.33 in.

2 ☐ Borehole Diameter 6 1/2 inches Depth 22' ft.

Casing Diameter 5 in. Length 60 ft. Thickness 0.35 in.

Casing Height Above Ground 2' ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐

2 ☐ 2 ☐ 2 ☐ 2 ☐ Other _____

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐

2 ☐ 2 ☐ 2 ☐ 2 ☐ Other _____

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material BENASEAL Volume/Weight Used 600 #

Method of Installation GRAVITY SLURRY

Depth: Placed FROM 0 ft. TO 30' ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>YELLOW CLAY</u>	<u>1</u>	<u>15</u>
<u>SAND STONE</u>	<u>15</u>	<u>58</u>
<u>GRAY SHALE</u>	<u>58</u>	<u>65</u>
<u>BROWN SANDSTONE</u>	<u>65</u>	<u>78</u>
<u>GRAY SHALE</u>	<u>78</u>	<u>95</u>

WATER 80'

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 7-1-08 Total Depth of Well 95 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy