

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 2045 Morse Road

1003867

Columbus, Ohio 43229-8605 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION

CONSTRUCTION DETAILS

County Laird Township BloomOwner/Builder Jason StortsAddress of Well Location 9710 alfordCity Coral Winchute Zip Code +4 3110Permit No. 2008-139 Section/Lot No. (Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well HouseN ☐ X ☐ +/- ft. or mS ☐ Y ☐ +/- ft. or mElevation of Well 911 ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation SourceSource of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat. Long.

North 39°48.326 82°38.62

South

WELL TEST*

Pre-Pumping Static Level 27 ft. Date 11-11-08Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other☐ Air ☐ Bailing ☒ Pumping* ☐ OtherTest Rate 15 gpm Duration of Test 1 hrs.Feet of Drawdown 5 ft. Sustainable Yield 15 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Catch Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality

PUMP/PITLESS

Type of pump Capacity gpm

Pump set at ft. Pitless Type

Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Shurt & SullinsAddress Box 65City, State, Zip Lithopolis, OH 43136Signed Harl Shurt Date 11-11-08ODH Registration Number 100☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BORERHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter inches Depth ft.Casing Diameter 6" 00 in. Length 118 ft. Thickness 188 in.2 ☐ Borehole Diameter inches Depth ft.Casing Diameter in. Length 16 ft. Thickness in.

Casing Height Above Ground ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ OtherJoints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Ben Seal Volume/Weight Used 100 lbMethod of Installation Dry Trowel

Depth: Placed FROM ft. TO ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:

sandstone, shale, limestone, gravel, clay, sand, etc.

From To

yellow clay + Gravel 0 15Blue clay + Gravel 15 89sand + clay 89 93Blue clay + Gravel 93 115sand 115 117 1/2Gravel 117 1/2 118Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNr, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy