

WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1004328

WELL LOCATION

County Franklin Township Harrison

Owner/Builder Clifford Smith
(Circle One or Both) First Last

Address of Well Location 2299 St. Rt. 40
Number Street Name

City Lewisburg Zip Code +4 5338

Permit No. 3060 Section/Lot No. _____
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Domestic


N ☐ X _____ +/- _____ ft. or m
S ☐ Y _____ +/- _____ ft. or m

Elevation of Well _____ ft. or m

Datum Plain: ☐ NAD27 ☒ NAD83 Elevation Source H.P.S.

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 39° 51.112' Long: 84° 35.184'

**CONSTRUCTION DETAILS**

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other _____

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 6 7/8" inches Depth 65 ft.
Casing Diameter 6 5/8" in. Length 30 ft. Thickness .188 in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 18"

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ _____
2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ Other _____

Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐ _____
2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ Other _____

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation N/A

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material Bentonite Volume/Weight Used 150 lbs.

Method of Installation pour

Depth: Placed FROM Surface ft. TO 30 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Top Soil	0	4
Hard Pan	4	23
Sand & Gravel	23	30
Limestone	30	65

Water @ 35'**WELL TEST***

Pre-Pumping Static Level 14 ft. Date 11/09/07

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other _____

☐ Air ☒ Bailing ☐ Pumping* ☐ Other _____

Test Rate 30 gpm Duration of Test 1 hrs.

Feet of Drawdown 2 ft. Sustainable Yield 30 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality Clear

PUMP/PITLESS

Type of pump Sub Capacity 10 gpm

Pump set at 55 ft. Pitless Type clearway

Pump installed by Carol Driller

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Phillips Hill Drilling

Address 4848 Farmant Rd.

City, State, Zip Lewisburg, Ohio 45338

Signed Edward C. Phillips Date 11/09/07

ODH Registration Number 313

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 11/09/07 Total Depth of Well 65 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy