

## CONSTRUCTION DETAILS

**GRAVEL PACK** (Filter Pack)

**GROUT**  
Material Bentonite Volume/Weight Used 90 lbs  
Method of Installation dry driven  
Depth: Placed FROM \_\_\_\_\_ ft. TO \_\_\_\_\_ ft.

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED:  
Show color, texture, hardness, and formation:  
sandstone, shale, limestone, gravel, clay, sand, etc.

[illegible]

\*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 6-26-07 Total Depth of Well 47 ft.

Pre-Pumping Static Level 18 ft. Date 6-28-07  
Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other \_\_\_\_\_  
☐ Air ☐ Bailing ☒ Pumping\* ☐ Other \_\_\_\_\_  
Test Rate 15 gpm Duration of Test 2 hrs.  
Feet of Drawdown 3 ft. Sustainable Yield 15 gpm  
\*(Attach a copy of the pumping test record, per section 1521.05, ORC)  
Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No  
Quality Clear

Type of pump Sub Capacity 12 gpm  
Pump set at 44 ft. Pitless Type 100  
Pump installed by Burnett

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Barrett Well Drilling  
Address 7777 4th St  
City, State, Zip Rockledge, FL

Signed [Signature] Date 7/20/11  
ODH Registration Number 511

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.  
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605  
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy