

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1006621

WELL LOCATION

CONSTRUCTION DETAILS

County Miami Township Monroe
 Owner/Builder Sylvia Reed
 (Circle One or Both) First Last
 Address of 1230 EDWARDS DR.
 Well Location Number Street Name
 City Tipp City Zip Code +4 45371
 Permit No. 398315 Section/Lot No.
 (Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well domestic


N ☐ X +/- ft. or m
 S ☐ Y +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:
 North



☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other
BOREHOLE/CASING (measured from ground surface)
 1 ☒ Borehole Diameter 5 9/8 inches Depth ft.
 Casing Diameter 6 in. Length 56 ft. Thickness .188 in.
 2 ☐ Borehole Diameter inches Depth ft.
 Casing Diameter in. Length ft. Thickness in.
 Casing Height Above Ground 14" ft.
 Type 1 ☐ Steel 1 ☒ Galv. 1 ☐ PVC 1 ☐ Other
 2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other
 Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐ Other
 2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter 4" Slot Size #0030 Screen Length 2 ft.
 Type PVC Material PVC
 Set Between 56 ft. and 57 ft.

GRAVEL PACK (Filter Pack)

Material/Size N/A Volume/Weight Used N/A
 Method of Installation N/A
 Depth: Placed FROM N/A ft. TO N/A ft.

GROUT

Material Bentomix Volume/Weight Used 150 lbs.
 Method of Installation dry pour
 Depth: Placed FROM 56 ft. TO Surface ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
 sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Surface	0	18"
GRAY SANDY CLAY + GRAVEL	18"	24'
Mixed CLAY + GRAVEL	24'	54'
GRAVEL - WATER BEARING	54'	96'
Shale - blue	96'	100'

WELL TEST*

Pre-Pumping Static Level 5 ft. Date 12-26-09
 Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other
☐ Air ☒ Bailing ☐ Pumping* ☐ Other
 Test Rate 5 gpm Duration of Test 2 hrs.
 Feet of Drawdown 30 ft. Sustainable Yield 5 gpm
 *(Attach a copy of the pumping test record, per section 1521.05, ORC)
 Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No
 Quality Clear

PUMP/PITLESS

Type of pump Submersible Capacity 10 gpm
 Pump set at 89 ft. Pitless Type BT-100
 Pump installed by Rick Stults

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Area Wide Well Drilling
 Address 2129 W. Plum St.
 City, State, Zip Tipp City OH 45371

Signed Rick Stults Date 1-12-10
 ODH Registration Number 1598

*(If more space is needed to complete drilling log, use next consecutively numbered form.)
 Date of Well Completion 12-26-09 Total Depth of Well 100 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
 ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
 Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy