


**WELL LOG AND DRILLING REPORT**TYPE OR USE PEN  
SELF TRANSCRIBING  
PRESS HARD

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1007470

**WELL LOCATION****CONSTRUCTION DETAILS**County Fairfield Township PleasantOwner/Builder Narrest A. Waller  
(Circle One or Both) First LastAddress of Well Location 523 Ireland  
Number Street NameCity Laurelton Zip Code +4 43063Permit No. 2007107 Section/Lot No. \_\_\_\_\_  
(Circle One or Both)Location of Well in State Plane  
coordinates, if available:N ☒ X 39.044, 017° +/- \_\_\_\_\_ ft. or mS ☒ Y 082, 42.304° +/- \_\_\_\_\_ ft. or mElevation of Well 1267 +/- \_\_\_\_\_ ft. or mDatum Plain: ☐ NAD27 ☒ NAD83 Elevation Source \_\_\_\_\_Source of Coordinates: ☒ GPS ☐ Survey ☐ Other \_\_\_\_\_Sketch a map showing distance well lies from numbered state highways, street  
intersections, county roads, buildings or other notable landmarks. If latitude and  
longitude are available please include here: Lat: \_\_\_\_\_ Long: \_\_\_\_\_  
North**WELL TEST\***Pre-Pumping Static Level 27 ft. Date 10/10/07Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other \_\_\_\_\_☐ Air ☒ Bailing ☐ Pumping\* ☐ Other \_\_\_\_\_Test Rate 15 gpm Duration of Test 1 hrs.Feet of Drawdown 0 ft. Sustainable Yield \_\_\_\_\_ gpm

\*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No ☒ Flowing Well? ☒ Yes ☐ NoQuality Clear**PUMP/PITLESS**Type of pump Submersible Capacity 15 gpmPump set at 50' ft. Pitless Type 1Pump installed by Narrest Casey

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Casey's Well DrillingAddress 321 Mt ZionCity, State, Zip 43130Signed Narrest Casey Date 10/10/07ODH Registration Number 1833☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other \_\_\_\_\_**BOREHOLE/CASING** (measured from ground surface)1 ☐ Borehole Diameter 5 inches Depth \_\_\_\_\_ ft.  
Casing Diameter 5 1/2 in. Length 57 ft. Thickness 0.235 in.2 ☐ Borehole Diameter \_\_\_\_\_ inches Depth \_\_\_\_\_ ft.  
Casing Diameter \_\_\_\_\_ in. Length \_\_\_\_\_ ft. Thickness \_\_\_\_\_ in.Casing Height Above Ground 18 ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ \_\_\_\_\_  
2 ☐ \_\_\_\_\_ 2 ☐ \_\_\_\_\_ 2 ☐ \_\_\_\_\_ 2 ☐ Other \_\_\_\_\_Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐ \_\_\_\_\_  
2 ☐ \_\_\_\_\_ 2 ☐ \_\_\_\_\_ 2 ☐ \_\_\_\_\_ 2 ☐ Other \_\_\_\_\_**SCREEN**

Diameter \_\_\_\_\_ Slot Size \_\_\_\_\_ Screen Length \_\_\_\_\_ ft.

Type \_\_\_\_\_ Material \_\_\_\_\_

Set Between \_\_\_\_\_ ft. and \_\_\_\_\_ ft.

**GRAVEL PACK** (Filter Pack)

Material/Size \_\_\_\_\_ Volume/Weight Used \_\_\_\_\_

Method of Installation \_\_\_\_\_

Depth: Placed FROM \_\_\_\_\_ ft. TO \_\_\_\_\_ ft.

**GROUT**Material Ben Seal Volume/Weight Used 200 lbMethod of Installation Pand and DrillDepth: Placed FROM 5' ft. TO 0 ft.**DRILLING LOG\***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:  
sandstone, shale, limestone, gravel, clay, sand, etc.

|                     | From | To |
|---------------------|------|----|
| Top Soil            | 0    | 2  |
| Brown and Clay      | 2    | 20 |
| Light Brown Stone   | 20   | 45 |
| Light Gray Red Sand | 45   | 60 |
| Blue Shell Stone    | 60   | 72 |

\*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 10/10/07 Total Depth of Well 72 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.  
**ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605**  
 Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy