

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD**WELL LOG AND DRILLING REPORT**

Ohio Department of Natural Resources


Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1007977

WELL LOCATIONCounty Greene Township MiamiOwner/Builder Larry Zevodnee
(Circle One or Both) First LastAddress of Well Location 4080 Kyle Rd
Number Street NameCity Cedarville Zip Code +4 45314Permit No. Section/Lot No.
(Circle One or Both)Location of Well in State Plane
coordinates, if available:N ☒ X 42° 22' 53" +/- ft. or mE ☒ Y 083° 09' 15" +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation SourceSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:
North**WELL TEST***Pre-Pumping Static Level 31 ft. Date 7-1-11Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other☒ Air ☐ Bailing ☐ Pumping* ☐ OtherTest Rate 7 gpm Duration of Test 1 hrs.Feet of Drawdown 30 ft. Sustainable Yield gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ NoQuality Clear**PUMP/PITLESS**

Type of pump Capacity gpm

Pump set at ft. Pitless Type

Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Lower Well DrillingAddress 2531 S. Limestone St.City, State, Zip SPfld, OhioSigned David V. Lower Date 7-1-11ODH Registration Number 204**CONSTRUCTION DETAILS**☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other**BOREHOLE/CASING** (measured from ground surface)1 ☒ Borehole Diameter 7 7/8 inches Depth 111 ft.Casing Diameter 5 in. Length 112 ft. Thickness 3/8 in.2 ☒ Borehole Diameter 4 3/4 inches Depth 24 ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ OtherJoints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other**SCREEN**

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUTMaterial Bentonite Volume/Weight Used 350 lbsMethod of Installation Trem PipeDepth: Placed FROM 111 ft. TO Surface ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Clay	0	6
Sandy Gravel	6	15
Gray Clay	15	108
Gray Limestone	108	123
Gray Shale	123	136

Encountered H₂O 112 123

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 7-1-11 Total Depth of Well 136 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
 ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
 Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy