


WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1007981

WELL LOCATIONCounty Clark Township HarmonyOwner/Builder Bob Stienberger
(Circle One or Both) First Last
Address of Well Location 6586 Plattsburg Rd
Number Street NameCity South Charleston Zip Code +4 45368Permit No. Section/Lot No.
(Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well DomesticN X 39° 54' 860 +/- ft. or mW X 083° 41' 008 +/- ft. or mElevation of Well 1110 +/- ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation SourceSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: North 39.914333° Long: -83.683467°**WELL TEST***Pre-Pumping Static Level 32 ft. Date 7-14-2010Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other☒ Air ☒ Bailing ☐ Pumping* ☐ OtherTest Rate _____ gpm Duration of Test 2 hrs.Feet of Drawdown 10 ft. Sustainable Yield 8 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ NoQuality Clear**PUMP/PITLESS**Type of pump Submersible Capacity 8 gpmPump set at 60 ft. Pitless TypePump installed by Gothard

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Lower Well Drilling Co.Address 2545 S. Limestone St.City, State, Zip SPfld, Ohio 45505Signed David V. JovanDate 7-14-2010ODH Registration Number 204**CONSTRUCTION DETAILS**☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other**BOREHOLE/CASING** (measured from ground surface)1. ☒ Borehole Diameter 7 7/8 inches Depth 76 ft.Casing Diameter 5 in. Length 76 ft. Thickness 3/8 in.2. ☐ Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground _____ ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐2 ☐ 2 ☐ 2 ☐ 2 ☐ OtherJoints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐2 ☐ 2 ☐ 2 ☐ 2 ☐ Other**SCREEN**Diameter 5 Slot Size #32 Screen Length 4 ft.Type Slotted Material PVCSet Between 70 ft. and 74 ft.**GRAVEL PACK** (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUTMaterial Ben-Seal Volume/Weight Used 250 lbsMethod of Installation Pressure PumpDepth: Placed FROM 40 ft. TO Surface ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Brown Clay</u>	<u>0</u>	<u>6</u>
<u>Brown Sand</u>	<u>6</u>	<u>36</u>
<u>Brown Sandy Gravel</u>	<u>36</u>	<u>56</u>
<u>Gray Sand & Gravel</u>	<u>56</u>	<u>69</u>
<u>Gray Gravel</u>	<u>69</u>	<u>76</u>

Encountered H₂O55 to 75

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 7-14-2010 Total Depth of Well 75 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
 ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
 Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy