

WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1008259

WELL LOCATION**CONSTRUCTION DETAILS**

County Cash Township White Flg

Owner/Builder Judy Schmitt
(Circle One or Both) First Last

Address of Well Location 52915 TR170
Number Street Name

City Fresno Zip Code +4 43824

Permit No. 2008-090 Section/Lot No.
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Home Use

N 41.40.30630° N +/- ft. or m

S 40.081.76437° W +/- ft. or m

Elevation of Well +842 +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source +842

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

☐ Rotary ☒ Cable ☐ Augered ☒ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☒ Borehole Diameter 7 1/2 inches Depth 35 ft.
Casing Diameter 5 1/2 in. Length 35 ft. Thickness 2.50 in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 18" ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other

2 ☐ Threading 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other

2 ☐ Threading 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter 4 1/2 Slot Size 1/4 Screen Length 30 ft.

Type Flush mount liner Material PVC

Set Between 90-70 ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material Panseal Volume/Weight Used 200

Method of Installation Grout Pour


Depth: Placed FROM 0 ft. TO 35 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.		From To	
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.		From	To
<u>Loam</u>		<u>0</u>	<u>4</u>
<u>Sandy Soil</u>		<u>4</u>	<u>35</u>
<u>Pink Clay</u>		<u>35</u>	<u>50</u>
<u>Dark Clay</u>		<u>50</u>	<u>55</u>
<u>Sandstone</u>		<u>55</u>	<u>60</u>
<u>Sandstone</u>		<u>60</u>	<u>70</u>

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 40.30630 Long: _____

North

**WELL TEST***

Pre-Pumping Static Level 20 ft. Date 4-21-09

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 6 gpm Duration of Test 2 hrs.

Feet of Drawdown 45 ft. Sustainable Yield 6 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☒ Yes ☐ No

Quality _____

PUMP/PITLESS

Type of pump Summit Capacity 12 gpm

Pump set at 60 ft. Pitless Type 1" moran

Pump installed by Moran's Water Well Service

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Moran's Water Well Service

Address 20677 CR3

City, State, Zip Walton, Ohio 43884

Signed Vince Moran Date 7-25-09

ODH Registration Number 002489

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 7-25-09 Total Depth of Well 70 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy