

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources


Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1008708

WELL LOCATION

CONSTRUCTION DETAILS

County Belmont Township YorkOwner/Builder Peter & Sarah Ruschak
(Circle One or Both) First LastAddress of Well Location 55840 Little Captaine
Number Street NameCity Powhatan Point, OH Zip Code +4 43949Permit No. 22 Section/Lot No.
(Circle One or Both)Location of Well in State Plane
coordinates, if available:Use of Well Home UseN ☐ X +/- ft. or mS ☐ Y +/- ft. or mElevation of Well +/- ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source Source of Coordinates: ☐ GPS ☐ Survey ☐ Other Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat 39.889 Long: -80.819
North☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 10 inches Depth 70 ft.
Casing Diameter 6 in. Length 72 ft. Thickness 1/2 in.2 ☐ Borehole Diameter inches Depth ft.
Casing Diameter in. Length ft. Thickness in.Casing Height Above Ground 24" ft.Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐
2 ☐ 2 ☐ 2 ☐ 2 ☐ Other Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐
2 ☐ 2 ☐ 2 ☐ 2 ☐ Other

SCREEN

Diameter 6" Slot Size 5/16 Screen Length 35 ft.Type PVC Material DrilledSet Between 35 ft. and 70 ft.

GRAVEL PACK (Filter Pack)

Material/Size #57 Gravel Volume/Weight Used 1500/lbsMethod of Installation poouredDepth: Placed FROM 26 ft. TO 70 ft.

GROUT

Material Ben Seal Volume/Weight Used 700/lbsMethod of Installation pooured aroundDepth: Placed FROM 0 ft. TO 25 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top Soil	0	2
Sandstone	2	12
Brown Shale	12	28
(WV) Gray Shale	28	41
Limestone	41	51
Brown Shale	51	62
Brown Limestone	62	70

WELL TEST*

Pre-Pumping Static Level 35 ft. Date 7/15/07Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other ☐ Air ☒ Bailing ☐ Pumping* ☐ Other Test Rate 1.5 gpm Duration of Test 2 hrs.Feet of Drawdown 30 ft. Sustainable Yield gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ NoQuality good

PUMP/PITLESS

Type of pump N/A Capacity gpmPump set at ft. Pitless Type Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm K+K Water Well DrillingAddress 45610 TH 2313City, State, Zip Lewisville, OH 43754Signed Kate Pence Date 7/17/07ODH Registration Number 003119

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 7/15/07 Total Depth of Well 70 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy