


WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1009874

WELL LOCATION**CONSTRUCTION DETAILS**County Summit Township SpringfieldOwner/Builder DALE CONNERS
(Circle One or Both) First LastAddress of Well Location 1586 Ambrose Dr.
Number Street NameCity AKRON Zip Code +4 44312Permit No. 389864 Section/Lot No. RESIDENTIAL
(Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well RESIDENTIALN ☐ X ☐ +/- ft. or mS ☐ Y ☐ +/- ft. or mElevation of Well 335' +/- ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source GPSSource of Coordinates: ☐ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 41°01'27" N Long: 81°26'08" W

South

WELL TEST*Pre-Pumping Static Level 20 ft. Date 6-20-08Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other☐ Air ☒ Bailing ☐ Pumping* ☐ OtherTest Rate 20 gpm Duration of Test 1 hrs.Feet of Drawdown 10 ft. Sustainable Yield 20 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality

PUMP/PITLESS

Type of pump Capacity gpm

Pump set at ft. Pitless Type

Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm COOPER WELL DRILLING INC.Address 2206 KILLIAN RDCity, State, Zip AKRON OHIO 44312Signed Carl Cooper Date 6-23-08ODH Registration Number 125☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other**BOREHOLE/CASING** (measured from ground surface)1 ☐ Borehole Diameter 5" inches Depth 85' ft.

Casing Diameter in. Length ft. Thickness in.

2 ☐ Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground 15" ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐2 ☐ 2 ☐ 2 ☐ 2 ☐ OtherJoints 1 ☐ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐2 ☐ 2 ☐ 2 ☐ 2 ☐ Other**SCREEN**

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUTMaterial #8 BENTONITE Volume/Weight Used 150 LBMethod of Installation DRYDepth: Placed FROM 0 ft. TO 83 ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

From To

BROWN CLAY & GRAVEL 0 39BLUE CLAY SAND & GRAVEL 39 59SHALE 59 85Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy