

WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1010338

WELL LOCATION**CONSTRUCTION DETAILS**

County Williams Township Madison

Owner/Builder Ron Hauser
(Circle One or Both) First Last

Address of Well Location 18239 Rd 15
Number Street Name

City Pioneer Zip Code +4 43554

Permit No. 601 Section/Lot No. 16
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Barn

N ☐ X 41 +/- 41.129 ft. or m
S ☐ Y 84 +/- 32.178 ft. or m

Elevation of Well 41.129 ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source GPS

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5 inches Depth 59 ft.
Casing Diameter 5.75 in. Length 55 ft. Thickness .258 in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 2 ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other _____
2 ☐ 2 ☐ 2 ☐ 2 ☐ Other _____

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other _____
2 ☐ 2 ☐ 2 ☐ 2 ☐ Other _____

SCREEN

Diameter 4" Slot Size 15 Screen Length 4 ft.

Type Wrip Wrapped Material S.S.

Set Between 55 ft. and 59 ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material Benseal Volume/Weight Used 75#

Method of Installation Dry Drilling

Depth: Placed FROM 0 ft. TO 45 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Topsoil</u>	<u>0</u>	<u>1</u>
<u>Brown Clay & gravel</u>	<u>1</u>	<u>9</u>
<u>Gray Clay mix</u>	<u>9</u>	<u>42</u>
<u>Hard Pan mix</u>	<u>42</u>	<u>52</u>
<u>Sand & Gravel & water</u>	<u>52</u>	<u>59</u>

WELL TEST*

Pre-Pumping Static Level 16 ft. Date 10-15-10

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other _____

☐ Air ☒ Bailing ☐ Pumping* ☐ Other _____

Test Rate 18 gpm Duration of Test 1/2 hrs.

Feet of Drawdown 2 ft. Sustainable Yield _____ gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality Clear

PUMP/PITLESS

Type of pump Sub Capacity 10 gpm

Pump set at 44 ft. Pitless Type adapter

Pump installed by Larry Rupp

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Rupp Well Drilling

Address 24-455 Rd 4

City, State, Zip Pioneer, Ohio 43557

Signed Larry Rupp Date 10-15-10

ODH Registration Number 1019

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 10-15-10 Total Depth of Well 59 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy