


TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD**WELL LOG AND DRILLING REPORT**Ohio Department of Natural Resources
Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1010493

WELL LOCATION		CONSTRUCTION DETAILS																			
County <u>Fairfield</u> Township <u>Rushcreek</u> Owner/Builder <u>Dorothy L. Seifert</u> Address of Well Location <u>165 Thomas Rd.</u> City <u>Bremen Ohio</u> Zip Code <u>+4 43107</u> Permit No. <u>2015-060</u> Section/Lot No. <u></u> Location of Well in State Plane coordinates, if available: N <u>39° 43' 17"</u> W <u>82° 25' 8"</u> Elevation of Well <u>845</u> ft. or m <u></u> Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source <u></u> Source of Coordinates: ☐ GPS ☐ Survey ☐ Other <u></u>		☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other <u></u> BOREHOLE/CASING (measured from ground surface) 1 ☐ Borehole Diameter <u>9</u> inches Depth <u>102</u> ft. Casing Diameter <u>5</u> in. Length <u>92</u> ft. Thickness <u>1/2</u> in. 2 ☐ Borehole Diameter <u>5</u> inches Depth <u>10</u> ft. Casing Diameter <u></u> in. Length <u></u> ft. Thickness <u></u> in. Casing Height Above Ground <u>24 in</u> ft. Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other <u></u> 2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other <u></u> Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐ Other <u></u> 2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other <u></u>																			
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: <u></u> Long: <u></u> 		SCREEN Diameter <u></u> Slot Size <u></u> Screen Length <u></u> ft. Type <u></u> Material <u></u> Set Between <u></u> ft. and <u></u> ft. GRAVEL PACK (Filter Pack) Material/Size <u></u> Volume/Weight Used <u></u> Method of Installation <u></u> Depth: Placed FROM <u></u> ft. TO <u></u> ft. GROUT Material <u>Bennetts Dry pack</u> Volume/Weight Used <u>8 X 50 lb</u> Method of Installation <u>top</u> Depth: Placed FROM <u></u> ft. TO <u>92</u> ft.																			
WELL TEST*		DRILLING LOG*																			
Pre-Pumping Static Level <u>20</u> ft. Date <u>6/2/15</u> Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other <u></u> ☐ Air ☒ Bailing ☐ Pumping* ☐ Other <u></u> Test Rate <u>20</u> gpm Duration of Test <u>3</u> hrs. Feet of Drawdown <u>30</u> ft. Sustainable Yield <u>20</u> gpm *(Attach a copy of the pumping test record, per section 1521.05, ORC) Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No Quality <u></u>		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.</th> <th style="text-align: center;">From</th> <th style="text-align: center;">To</th> </tr> </thead> <tbody> <tr> <td>Brown Bank Run</td> <td style="text-align: center;">0</td> <td style="text-align: center;">20</td> </tr> <tr> <td>Blue Mud</td> <td style="text-align: center;">20</td> <td style="text-align: center;">90</td> </tr> <tr> <td>Grey Sandstone</td> <td style="text-align: center;">90</td> <td style="text-align: center;">100</td> </tr> <tr> <td>Hard Ligne</td> <td style="text-align: center;">100</td> <td style="text-align: center;">102</td> </tr> <tr> <td>Total Depth</td> <td></td> <td></td> </tr> </tbody> </table>		INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.	From	To	Brown Bank Run	0	20	Blue Mud	20	90	Grey Sandstone	90	100	Hard Ligne	100	102	Total Depth		
INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.	From	To																			
Brown Bank Run	0	20																			
Blue Mud	20	90																			
Grey Sandstone	90	100																			
Hard Ligne	100	102																			
Total Depth																					
PUMP/PITLESS																					
Type of pump <u>1/2 HP Aeromath</u> Capacity <u></u> gpm Pump set at <u>90</u> ft. Pitless Type <u>Standard</u> Pump installed by <u>Driller</u> I hereby certify the information given is accurate and correct to the best of my knowledge. Drilling Firm <u>Ross Water Well Drilling</u> Address <u>3654 Logan THORNTON RD</u> City, State, Zip <u>Bremen, Ohio 43107</u> Signed <u>Ross</u> Date <u>6/10/15</u> ODH Registration Number <u>159</u>		*(If more space is needed to complete drilling log, use next consecutively numbered form.) Date of Well Completion <u>6/15/15</u> Total Depth of Well <u>102</u> ft.																			