


WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 2045 Morse Road
Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1011421

WELL LOCATIONCounty Greene Township SilvercreekOwner/Builder Dan Shusher
(Circle One or Both) First LastAddress of Well Location 1543 Hite Rd.
Number Street NameCity Jamestown Zip Code +4 45335Permit No. 988828 Section/Lot No. (Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well Single family dwellingN ☐ X ☐ +/- 1 ft. or mS ☐ Y ☐ +/- 1 ft. or mElevation of Well 1062 +/- 15 ft. or mDatum Plain: ☐ NAD27 ☒ NAD83 Elevation Source GPSSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: N39°37'49.4" Long: W083°46'13.8"**WELL TEST***Pre-Pumping Static Level 29 ft. Date 10-12-10Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other☒ Air ☐ Bailing ☐ Pumping* ☐ OtherTest Rate 20 gpm Duration of Test 1 hrs.Feet of Drawdown aprox 15 ft. Sustainable Yield aprox 15 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ NoQuality Clear**PUMP/PITLESS**Type of pump pitless Capacity 1 gpmPump set at 1 ft. Pitless Type 1Pump installed by White-Well Drilling LLC

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm White-Well Drilling LLCAddress 480 Kinsley RdCity, State, Zip Kenna, Ohio 45385Signed John E White Date 10-14-10ODH Registration Number 15**CONSTRUCTION DETAILS**☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other**BOREHOLE/CASING** (measured from ground surface)1 ☒ Borehole Diameter 7 1/8 inches Depth 72 ft.Casing Diameter 5 in. Length 72 ft. Thickness 30R2 in.2 ☐ Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 1 1/2 ft.Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐ Other2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ OtherJoints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐ Other2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other**SCREEN**Diameter 5 Slot Size 125 Screen Length 4 ft.Type Slotted Material PVCSet Between 68 ft. and 72 ft.**GRAVEL PACK** (Filter Pack)Material/Size 1/2 pea gravel Volume/Weight Used 25 galMethod of Installation pourDepth: Placed FROM 72 ft. TO 67 ft.**GROUT**Material Benzol Volume/Weight Used 350 galMethod of Installation grout pumpDepth: Placed FROM 67 ft. TO 0 ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Clay	0	30
gravel	30	46
Clay	46	65
sand & gravel - 'Water'	65	72
Water @ 65-72'		

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy