


WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1011485

WELL LOCATION**CONSTRUCTION DETAILS**County MONTGOMERY Township BUTLEROwner/Builder MIKE HAWK HOMES LLC.
(Circle One or Both) First LastAddress of Well Location 6260 FREDERICK PIKE
Number Street NameCity DAYTON OHIO Zip Code +4 45414Permit No. WS-08-18 Section/Lot No.
(Circle One or Both)Location of Well in State Plane
coordinates, if available:N 39-50.250 +/- ft. or mS 1084-13.398 +/- ft. or mElevation of Well 848 +/- ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation SourceSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street
intersections, county roads, buildings or other notable landmarks. If latitude and
longitude are available please include here: Lat: 084° Long: 39°☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other**BOREHOLE/CASING** (measured from ground surface)1 ☐ Borehole Diameter 5 1/2 inches Depth 130 ft.Casing Diameter 6 in. Length 44 ft. Thickness 188 in.2 ☐ Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground _____ ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ OtherJoints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other**SCREEN**

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUTMaterial Bentonite Volume/Weight Used 40 #Method of Installation Dry drivenDepth: Placed FROM 0 ft. TO 38 ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Clay 0 10SAND-GRAVEL 10 12CLAY-GRAVEL 12 20CLAY 20 38SAND-GRAVEL 38 41Blue Shale 41 130Water @ 41'**WELL TEST***Pre-Pumping Static Level 15 ft. Date 9-24-2008Measured from ☒ Top of Casing ☐ Ground Level ☐ OtherAir ☐ Bailing ☐ Pumping* ☐ OtherTest Rate 4 gpm Duration of Test 2 hrs.Feet of Drawdown 100 ft. Sustainable Yield 4 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ NoQuality Clean**PUMP/PITLESS**Type of pump 1/2 HP Submersible Capacity 10 gpmPump set at 120 ft. Pitless Type SIMMONSPump installed by Glasier Water

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm GLASIER WATER SERVICE INC.Address 1330 E EVANSTON RDCity, State, Zip TIPP CITY OHIO 45371Signed James J. Glasier Date 10-2-08ODH Registration Number 0385

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 9-24-08 Total Depth of Well 130 ft.Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy