

WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources


Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1011487

WELL LOCATION**CONSTRUCTION DETAILS**County MIAMI Township BothelOwner/Builder
(Circle One or Both)First STEVE Last GLASERAddress of
Well LocationNumber 5255 Street Name Rudy RdCity TIPP City OHIO Zip Code +4 45371Permit No. 384412 Section/Lot No. 23
(Circle One or Both)Location of Well in State Plane
coordinates, if available:N 39° 57.214' +/- 0.004' ft. or mS 084° 07.177' +/- 0.004' ft. or mElevation of Well 820 +/- 0 ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation SourceSource of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other**BOREHOLE/CASING** (measured from ground surface)1 ☐ Borehole Diameter 5 1/2 inches Depth 100 ft.Casing Diameter 6 in. Length 49 ft. Thickness .188 in.2 ☐ Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground _____ ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ OtherJoints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other**SCREEN**Diameter 6 Slot Size 1/8" Screen Length 3 ft.Type PERFORATED Material STEELSet Between 44 ft. and 47 ft.**GRAVEL PACK** (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUTMaterial BENTONITE Volume/Weight Used 40*Method of Installation Dry drivenDepth: Placed FROM 0 ft. TO 40 ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
TOP SOIL	0	1
CLAY	1	9
SAND-GRAVEL-CLAY	9	20
CLAY	20	24
SAND-GRAVEL-CLAY	24	40
SAND-GRAVEL	40	47
Blue Shale	47	62
Limestone	62	65
Blue Shale	65	100

WELL TEST*Pre-Pumping Static Level 15 ft. Date 9-11-2008Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other☐ Air ☒ Bailing ☐ Pumping* ☐ OtherTest Rate 6 gpm Duration of Test 2 hrs.Feet of Drawdown 80 ft. Sustainable Yield 6 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☒ Yes ☐ No Flowing Well? ☐ Yes ☒ NoQuality Clear**PUMP/PITLESS**Type of pump 1/2 HP Submersible Capacity 10 gpmPump set at 90 ft. Pitless Type SimmonsPump installed by GLASER WATER

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm GLASER WATER SERVICE INC.Address 1330 E. EVANSTON RDCity, State, Zip TIPP City OHIO 45371Signed Paul R. Isler Date 10-4-08ODH Registration Number 0385

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 9-26-08 Total Depth of Well 100 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
 ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
 Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy