

WELL LOG AND DRILLING REPORT

1011491

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road


Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOCATION

County Miami Township Lost CreekOwner/Builder DASON POEPPELMAN
(Circle One or Both) First LastAddress of Well Location 7405 Green Rd
Number Street NameCity CASSTOWN, OHIO Zip Code +4 45312Permit No. 384434 Section/Lot No. 8
(Circle One or Both)

Location of Well in State Plane coordinates, if available:

N ☒ X 40° 04' 400 +/- ft. or mS ☒ Y 084° 03' 601 +/- ft. or mElevation of Well 984' +/- ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation SourceSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 084 Long: 40

WELL TEST*

Pre-Pumping Static Level 40 ft. Date 10-16-2008Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other☐ Air ☒ Bailing ☐ Pumping* ☐ OtherTest Rate 20 gpm Duration of Test 2 hrs.Feet of Drawdown 10 ft. Sustainable Yield 20 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ NoQuality Chenn

PUMP/PITLESS

Type of pump 1/2 HP Sub. Capacity 10 gpmPump set at 20 ft. Pitless Type SIMMONSPump installed by GLASER WATER SERVICE INC.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm GLASER WATER SERVICE INC.Address 1330 E. Evansdale RdCity, State, Zip Tipp City, OHIO 45371Signed [Signature] Date 10-28-08ODH Registration Number 0385

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5 1/2 inches Depth 116 ft.Casing Diameter 6 in. Length 91 ft. Thickness 188 in.2 ☐ Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground _____ ft.

Type ☒ Steel ☐ Galv. ☐ PVC ☐ Other2 ☐ Steel ☐ Galv. ☐ PVC ☐ OtherJoints ☐ Threaded ☒ Welded ☐ Solvent ☐ Other2 ☐ Threaded ☐ Welded ☐ Solvent ☐ Other

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material Bestonite Volume/Weight Used 80*Method of Installation Dry downDepth: Placed FROM 0 ft. TO 90 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top Soil	0	1
Clay	1	55
Gravel	55	56
chert	56	90
Limestone	90	116

WATER @ 102'

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 10-16-08 Total Depth of Well 116 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy