


TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD**WELL LOG AND DRILLING REPORT**

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1011670

WELL LOCATIONCounty TUSCARAWAS Township SANDYOwner/Builder WARREN SCHNIEDER
(Circle One or Both) First LastAddress of Well Location 4427 PARK AVE
Number Street NameCity SANDYVILLE, OH Zip Code +4 44671Permit No. 502 106 Section/Lot No. (Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well DOMESTICN ☒ X 40.64 +/- 42 ft. or mS ☐ Y -81.38 +/- 94 ft. or mElevation of Well 982 +/- ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation SourceSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____
North**WELL TEST***Pre-Pumping Static Level 60 ft. Date 5-1-11
Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other
Air ☒ Bailing ☐ Pumping* ☐ Other
Test Rate 10 gpm Duration of Test _____ hrs.
Feet of Drawdown 20 ft. Sustainable Yield 10 gpm
*(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No
Quality 106 GR. H. 1.1 PPM IRON 7.1 PH**PUMP/PITLESS**Type of pump _____ Capacity _____ gpm
Pump set at _____ ft. Pitless Type _____
Pump installed by GENES PUMPS INSTALLED
I hereby certify the information given is accurate and correct to the best of my knowledge.
Drilling Firm PEARSON & KELLER INC
Address 5288 SE 212 NW
City, State, Zip BEACH CITY, OH 44608
Signed [Signature] Date 5-5-11
ODH Registration Number 0050**CONSTRUCTION DETAILS**☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other**BOREHOLE/CASING** (measured from ground surface)1 ☒ Borehole Diameter 5" inches Depth 123 ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground _____ ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ OtherJoints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other**SCREEN**Diameter 5" Slot Size .30 Screen Length 3' ft.Type STAINLESS Material STAINLESS STEELSet Between 121' ft. and 123' ft.**GRAVEL PACK (Filter Pack)**Material/Size LOCAL Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUTMaterial BEATONITE Volume/Weight Used 150#Method of Installation DRY DRIVENDepth: Placed FROM 0' ft. TO 120' ft.**DRILLING LOG***INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
CLAY - LOCAL GRAVEL	0	68
MUD - LOCAL MIX	68	90
GREEN SAND & GRAVEL (W)	90	123

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy