

WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

1013089

WELL LOCATION**CONSTRUCTION DETAILS**

County Hocking Township Perry

Owner/Builder Dave Vangundy
(Circle One or Both) First Last

Address of Well Location 16019 Hunt Rd.
Number Street Name

City Laurelville Zip Code +4 43135

Permit No. Livestock Section/Lot No. _____
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Livestock

N ☐ X _____ +/- _____ ft. or m

S ☐ Y _____ +/- _____ ft. or m

Elevation of Well _____ +/- _____ ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other _____

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other _____

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5 inches Depth 175 ft.
Casing Diameter 5.500 in. Length 150 ft. Thickness 256 in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 24 ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ _____
2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ Other _____

Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ _____
2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ Other _____

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material Ben Seal Volume/Weight Used 375 lbs

Method of Installation Back filled as Driven

Depth: Placed FROM 148 ft. TO Surface ft.


DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Clay	0	8
Gray Clay & Gravel mix	8	61
Brown Sandy Clay	61	83
Gray Sticky Clay	83	129
Brown Clay	129	141
Gray Shale	141	146
Brown Sandstone	146	152
Gray Sandstone	152	173
Gray Sandy Shale	173	175

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____

**WELL TEST***

Pre-Pumping Static Level 85 ft. Date 4-21-2010

Measured from: ☒ Top of Casing ☒ Ground Level ☐ Other _____

☐ Air ☒ Bailing ☐ Pumping* ☐ Other _____

Test Rate 9.79 gpm Duration of Test 1 1/2 hrs.

Feet of Drawdown 79 ft. Sustainable Yield 8 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality Clear

PUMP/PITLESS

Type of pump Submersible Capacity 10 gpm

Pump set at 160 ft. Pitless Type Adapter

Pump installed by Tom Gobel Well Drilling

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Tom Gobel Well Drilling

Address 10919 Pin Zanesville Rd

City, State, Zip Amanda Ohio 43102

Signed Chris Gobel Date 4-21-10

ODH Registration Number 108

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 4-21-2010 Total Depth of Well 175 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy