


WELL LOG AND DRILLING REPORT

1015502

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION

County Gallia Township GreenfieldOwner/Builder Ken Evans
(Circle One or Both) First LastAddress of Well Location 3376 Gallia Rd.
Number Street NameCity OAK Hill Zip Code +4 45656Permit No. 388997 Section/Lot No. 10
(Circle One or Both)Location of Well in State Plane
coordinates, if available:Use of Well Private/Res. DwellN ☒ X 38 50.47 ft. or mW ☒ Y 82 29.997 ft. or mElevation of Well 652 ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source GPSSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street
intersections, county roads, buildings or other notable landmarks. If latitude and
longitude are available please include here: Lat: Long:

WELL TEST*

Pre-Pumping Static Level 28 ft. Date 11-5-17Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other☐ Air ☐ Bailing ☒ Pumping* ☐ OtherTest Rate 20 gpm Duration of Test 3 hrs.Feet of Drawdown 6 ft. Sustainable Yield 20+ gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☒ Yes ☐ NoQuality Clear, 3 parts Iron Good

PUMP/PITLESS

Type of pump Submersible Capacity 10 gpmPump set at 35 ft. Pitless Type Through CasingPump installed by Ron Johnson Drilling

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Ron Johnson DrillingAddress 258, Pct. 615 Twp Rd 205City, State, Zip Proctorville OH 45669Signed Ron Johnson Date 11-5-17ODH Registration Number 01923

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☒ Borehole Diameter 10 inches Depth 25 ft.Casing Diameter 6 in. Length 25 ft. Thickness 5/8 in.2 ☒ Borehole Diameter 6 inches Depth 40 ft.Casing Diameter 4 in. Length 35 ft. Thickness 3/8 in.Casing Height Above Ground 3 ft.Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐2 ☐ Steel 2 ☐ Galv. 2 ☒ PVC 2 ☐ OtherJoints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐2 ☐ Threaded 2 ☐ Welded 2 ☒ Solvent 2 ☐ Other

SCREEN

Diameter 4" Slot Size 014 Screen Length 10' ft.Type PVC MaterialSet Between 30/40' ft. and 40' ft.

GRAVEL PACK (Filter Pack)

Material/Size Pea Gravel Volume/Weight Used 50#Method of Installation PourDepth: Placed FROM 30 ft. TO 40 ft.

GROUT

Material Bentnite Volume/Weight Used 450#Method of Installation Dry PourDepth: Placed FROM 3 ft. TO 25' ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top Soil, Clay, Chunks of Sandstone	0	10'
Yellow, Brown Sandstone. Soft	10'	28
Brown, Grey Sandstone. Firm	28	37'
Brown Sandstone. Soft, "Water"	37'	40'
Pyroxenite, or Flint. Hard	40'	

After 3 hrs pumping
water finally cleared good
quality heavy iron 3 ppm

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 11-5-17 Total Depth of Well 40' ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy