

WELL LOCATION		CONSTRUCTION DETAILS																
County <u>Allen</u> Township <u>Jackson</u> Owner/Builder <u>Steve Friesner</u> Address of Well Location <u>4060 Sweeney Rd</u> City <u>Harrod</u> Zip Code +4 <u>45850</u> Permit No. <u>18-17</u> Section/Lot No. <u></u> Location of Well in State Plane coordinates, if available: Use of Well <u>Home</u> N <u>40° 47' 920</u> +/- <u>15</u> ft. or m W <u>83° 57' 017</u> +/- <u>15</u> ft. or m Elevation of Well <u>910</u> +/- <u>15</u> ft. or m Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source <u>GPS</u> Source of Coordinates: ☒ GPS ☐ Survey ☐ Other		☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other BOREHOLE/CASING (measured from ground surface) 1 ☐ Borehole Diameter <u>5 1/2</u> inches Depth <u>41</u> ft. Casing Diameter <u>6</u> in. Length <u>39</u> ft. Thickness <u>188</u> in. 2 ☐ Borehole Diameter _____ inches Depth _____ ft. Casing Diameter _____ in. Length _____ ft. Thickness _____ in. Casing Height Above Ground _____ ft. Type 1 ☒ Steel 1 ☒ Galv. 1 ☐ PVC 1 ☐ 2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ 2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other																
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____ North _____ South _____ West _____ East _____ 		SCREEN Diameter _____ Slot Size _____ Screen Length _____ ft. Type _____ Material _____ Set Between _____ ft. and _____ ft. GRAVEL PACK (Filter Pack) Material/Size _____ Volume/Weight Used _____ Method of Installation _____ Depth: Placed FROM _____ ft. TO _____ ft. GROUT Material <u>Bentonite Gravel</u> Volume/Weight Used <u>80#</u> Method of Installation <u>Gravity</u> Depth: Placed FROM <u>0</u> ft. TO <u>39</u> ft.																
WELL TEST* Pre-Pumping Static Level <u>18</u> ft. Date <u>OCT 2017</u> Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other ☐ Air ☒ Bailing ☒ Pumping* ☐ Other Test Rate <u>7</u> gpm Duration of Test <u>6</u> hrs. Feet of Drawdown <u>4</u> ft. Sustainable Yield <u>5.5</u> gpm *(Attach a copy of the pumping test record, per section 1521.05, ORC) Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No Quality <u>Clear No. Small</u>		DRILLING LOG* INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc. <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">From</th> <th style="text-align: center;">To</th> </tr> </thead> <tbody> <tr> <td>Brown Clay & Sand</td> <td style="text-align: center;">0</td> <td style="text-align: center;">15</td> </tr> <tr> <td>Blue Gray Clay</td> <td style="text-align: center;">15</td> <td style="text-align: center;">35</td> </tr> <tr> <td>Blue Gray Clay Sand</td> <td style="text-align: center;">35</td> <td style="text-align: center;">39</td> </tr> <tr> <td>Limestone Shale</td> <td style="text-align: center;">39</td> <td style="text-align: center;">41</td> </tr> </tbody> </table>			From	To	Brown Clay & Sand	0	15	Blue Gray Clay	15	35	Blue Gray Clay Sand	35	39	Limestone Shale	39	41
			From	To														
Brown Clay & Sand	0	15																
Blue Gray Clay	15	35																
Blue Gray Clay Sand	35	39																
Limestone Shale	39	41																
PUMP/PITLESS Type of pump _____ Capacity _____ gpm Pump set at _____ ft. Pitless Type _____ Pump installed by _____ I hereby certify the information given is accurate and correct to the best of my knowledge. Drilling Firm <u>Waldron Well Drilling</u> Address <u>5757 Rockport Rd</u> City, State, Zip <u>Columbus, Ohio 45830</u> Signed <u>Rustie Waldron</u> Date <u>OCT 17</u> ODH Registration Number <u>17666</u>		Water AT 40 ft (If more space is needed to complete drilling log, use next consecutively numbered form.) Date of Well Completion <u>OCT-17</u> Total Depth of Well <u>41</u> ft.																

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.