


WELL LOCATION **CONSTRUCTION DETAILS**

County Licking Township Newark
Owner/Builder (Circle One or Both) Keith STOSTRAND
First Last

Address of Well Location 2023 Fallsburg Rd.
Number Street Name
City Newark Zip Code +4 43055
Permit No. 10843 Section/Lot No. _____
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Single Family
N ☐ X _____ +/- _____ ft. or m
S ☐ Y _____ +/- _____ ft. or m
Elevation of Well 1085' +/- _____ ft. or m
Datum Plain: ☒ NAD27 ☐ NAD83 Elevation Source GPS
Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____



WELL TEST*

Pre-Pumping Static Level 150 ft. Date 9-21-16
Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other _____
☒ Air ☐ Bailing ☐ Pumping* ☐ Other _____
Test Rate 10 gpm Duration of Test 1 hrs.
Feet of Drawdown 0 ft. Sustainable Yield 10 gpm
*(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No
Quality Clear

PUMP/PITLESS

Type of pump Submersible Capacity 8 gpm
Pump set at 345 ft. Pitless Type Pull Through
Pump installed by Steve Neffers
I hereby certify the information given is accurate and correct to the best of my knowledge.
Drilling Firm STEVEN W. NEFFERS DRILLING
Address 10025 WILKINS RUN RD
City, State, Zip NEWARK OHIO 43055

Signed Steve Neffers Date 9-21-16
ODH Registration Number 969

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other _____
BOREHOLE/CASING (measured from ground surface)
1 ☒ Borehole Diameter 9 inches Depth 152 ft.
Casing Diameter 6.625 in. Length 152 ft. Thickness SDR 20 in.
2 ☒ Borehole Diameter 5 5/8 inches Depth 360 ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.
Casing Height Above Ground 18" ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐ _____
2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ _____
Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐ _____
2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ _____

SCREEN N.A.
Diameter _____ Slot Size _____ Screen Length _____ ft.
Type _____ Material _____
Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack) N.A.
Material/Size _____ Volume/Weight Used 480# 230

Method of Installation _____
Depth: Placed FROM _____ ft. TO _____ ft.

GROUT 480# 230
Material SENSE - EZ Mix Volume/Weight Used 9 gals
Method of Installation grout pump - tremie tube
Depth: Placed FROM 152 ft. TO SURFACE ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.		
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.	From	To
Brown Sandstone	0	30
Yellow Clay	30	85
Gray Shale	85	152
Yellow Sandstone	152	250
Union Sandstone	250	360
Water at 300'		

*(If more space is needed to complete drilling log, use next consecutively numbered form.)
Date of Well Completion 9-21-16 Total Depth of Well 360 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy