

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

1017915

WELL LOCATION

County Cashockton Township Lafayette

Owner/Builder ZAC M.H.R
(Circle One or Both) First Last

Address of Well Location 21544 TR 156
Number Street Name

City W. LA. Zip Code +4

Permit No. 2016-045 Section/Lot No.
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Single well

N ☐ X +/- ft. or m

S ☐ Y +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

West

BAY

Well

House

TR 156

South

East

North

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5 inches Depth 34 ft.

Casing Diameter 5 in. Length 32 ft Thickness 225 in.

2 ☐ Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft Thickness in.

Casing Height Above Ground ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐

2 ☐ 2 ☐ 2 ☐ 2 ☐ Other

1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐

2 ☐ 2 ☐ 2 ☐ 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Bent Seal Volume/Weight Used 120 #

Method of Installation Dry Mix

Depth: Placed FROM 0 ft. TO 32 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

From

To

025

2534

West

East

WELL TEST*

Pre-Pumping Static Level 1 ft. Date

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

☐ Air ☐ Bailing ☐ Pumping* ☐ Other

Test Rate 20 gpm Duration of Test 2 hrs.

Feet of Drawdown ft. Sustainable Yield 20 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No

Quality

PUMP/PITLESS

Type of pump Sub Capacity gpm

Pump set at 32 ft. Pitless Type Simmons

Pump installed by ACE

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm ACE Drilling

Address 19138 TR 5

City, State, Zip W. LA. OH 43846

Signed Tom Zachard Date

ODH Registration Number 1152

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion Total Depth of Well 34 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy