


TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

1018040

WELL LOCATION

County Allen Township JacksonOwner/Builder Radney Chapman
(Circle One or Both) First LastAddress of Well Location 959 McClure Rd
Number Street NameCity Sima, Ohio 45801 Zip Code +4 45801Permit No. 14-14 Section/Lot No. 25
(Circle One or Both)Location of Well in State Plane
coordinates, if available:N ☐ X +/- ft. or mS ☐ Y +/- ft. or mElevation of Well +/- 924 ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source GPSSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street
intersections, county roads, buildings or other notable landmarks. If latitude and
longitude are available please include here: Lat: Long: 

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5 1/2 inches Depth 48 ft.
Casing Diameter 6 in. Length 42 ft Thickness 188 in.2 ☐ Borehole Diameter inches Depth ft.
Casing Diameter in. Length ft Thickness in.Casing Height Above Ground ft.Type 1 ☒ Steel 1 ☒ Galv. 1 ☐ PVC 1 ☐ Other2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ OtherJoints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.Type Material Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used Method of Installation Depth: Placed FROM ft. TO ft.

GROUT

Material bentseal Volume/Weight Used 100lbsMethod of Installation from top while driving pipeDepth: Placed FROM 0 ft. TO 42 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Clay yellow	0	28
Clay gray	28	42
shale & limestone	42	48

WELL TEST*

Pre-Pumping Static Level 32 ft. Date Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other☐ Air ☐ Bailing ☒ Pumping* ☐ OtherTest Rate 20 gpm Duration of Test 1/2 hrs.Feet of Drawdown 5 ft. Sustainable Yield 20 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☒ NoQuality good

PUMP/PITLESS

Type of pump submersible Capacity 10 gpmPump set at 45 ft. Pitless Type pull-throughPump installed by Tom Byrne

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Tom Byrne Well Drilling Co.Address 3030 Marion Pl.City, State, Zip Sima, Ohio 45806Signed Tom Byrne Date 11-12-14ODH Registration Number 924

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 11-12-14 Total Depth of Well 48 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy