

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

County Medina Township Orange

Owner/Builder (Circle One or Both) Artisan Builders

Address of Well Location 4780 Dunshard Rd

City Medina Zip Code +4 44056

Permit No. 519617 Section/Lot No.

Location of Well in State Plane coordinates, if available: Use of Well house

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source GPS

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 41° 08' 21.5" N Long: 82° 42' 43.1" W

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☒ Borehole Diameter 4 7/8 inches Depth 100 ft

Casing Diameter 5 in. Length 74 ft Thickness 25 in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft

Casing Diameter _____ in. Length _____ ft Thickness _____ in.

Casing Height Above Ground _____ ft

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft

Type _____ Material _____

Set Between _____ ft and _____ ft

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft TO _____ ft

GROUT

Material Ben seal Volume/Weight Used 150 lbs

Method of Installation Dry pour casing driven

Depth: Placed FROM 72 ft TO grade ft

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown clay + sand	0	12
gray clay sand + gravel	12	31
Brown Sandstone	31	33
gray clay sand + gravel	33	65
light Brown Sandstone	65	100

Pre-Pumping Static Level 43 ft. Date 7-15-16

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 15+ gpm Duration of Test 1 1/2 hrs.

Feet of Drawdown 22 ft. Sustainable Yield 15 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality Clear

PUMP/PITLESS

Type of pump Sub Capacity 10 gpm

Pump set at 20 ft. Pitless Type CDSCO

Pump installed by Dugan

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Dugan Builders

Address 3459 Orange

City, State, Zip Medina OH 44056

Signed Frank Dugan Date 7-15-16

ODH Registration Number 384

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy