

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

1018799

WELL LOCATION

County COLUMBIANA Township HANOVER

Owner/Builder Dallas Strong
First Last

Address of Well Location 33823 U.S. 30 Lisbon, Ohio
Number Street Name

City Lisbon Zip Code +4 44432


Permit No. 9635 Section/Lot No. PRIVATE
(Circle One or Both)

Location of Well in State Plane coordinates, if available:
N ☒ X N 40° 45' 96" +/- ft. or m.
S ☐ Y W 080° 51' 63" +/- ft. or m.
Elevation of Well 1226 ft. or m.

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source 1226

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____



WELL TEST*

Pre-Pumping Static Level 88 ft. Date 8-3-21

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 20 gpm Duration of Test 2 hrs.

Feet of Drawdown _____ ft. Sustainable Yield 20 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality Clear, No odor or taste

PUMP/PITLESS

Type of pump Submersible Capacity _____ gpm

Pump set at 145 ft. Pitless Type Simmons

Pump installed by Smith Drilling Co.

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Smith Drilling Co.

Address 70 Box 213

City, State, Zip Chester, WV 26034

Signed Tracy Reed Date 8-6-21

ODH Registration Number 137

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 11 inches Depth 155 ft.
Casing Diameter 6 5/8 in. Length 42 ft. Thickness 188 in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 14 inches

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other 148' Liner

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other sch. 40 PVC

SCREEN

Diameter N/A Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size N/A Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT Bentonite Volume/Weight Used 1250 LBS.

Method of Installation Poured around outside of casing

Depth: Placed FROM 0 ft. TO 42 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.		From	To
Brown Clay & shale		0	12
Gray Clay		12	15
Brown Limestone		15	21
Gray Shale		21	27
Dark Gray shale		27	58
Gray Sandstone		58	98
Water			92
Gray Shale		98	147
Dark Gray Shale		147	155

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy