


WELL LOCATION

County Washington Township Muskingum
Owner/Builder Warren Water & Sewer
Address of Well Location 838 BF Goodrich Rd
City Maricetta Zip Code +4 45750
Permit No. _____ Section/Lot No. _____
Location of Well in State Plane coordinates, if available: Use of Well Potable
N ☐ X 39°27'16" +/- _____ ft. or m
S ☐ Y 81°27'52" +/- _____ ft. or m
Elevation of Well 670 +/- _____ ft. or m
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source Google
Source of Coordinates: ☐ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____



WELL TEST*

Pre-Pumping Static Level 58.7 ft. Date 2-21-24
Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other _____
☐ Air ☐ Bailing ☐ Pumping* ☐ Other _____
Test Rate 1200 gpm Duration of Test 24 hrs.
Feet of Drawdown 7.5 ft. Sustainable Yield 800 gpm
*(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☒ Yes ☐ No Flowing Well? ☐ Yes ☒ No
Quality _____

PUMP/PITLESS

Type of pump Not Installed Capacity _____ gpm
Pump set at _____ ft. Pitless Type _____
Pump installed by _____

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm The Ohio Drilling Company
Address 2405 Bostic Blvd
City, State, Zip Massillon OH

Signed Alex Axelsen Date 3-12-24
ODH Registration Number _____

CONSTRUCTION DETAILS

☐ Rotary ☐ Cable ☒ Augered ☐ Driven ☐ Other _____
BOREHOLE/CASING (measured from ground surface)
1 ☐ Borehole Diameter 48 inches Depth 88 ft.
Casing Diameter 42 in. Length 71 ft. Thickness _____ in.
2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter 16 in. Length 71 ft. Thickness _____ in.
Casing Height Above Ground _____ ft.
Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other _____
2 ☒ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other _____
Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐ Other _____
2 ☐ Threaded 2 ☒ Welded 2 ☐ Solvent 2 ☐ Other _____

SCREEN

Diameter 16" Slot Size 90 Screen Length 17 ft.
Type wire wound Material stainless
Set Between 71 ft. and 88 ft.

GRAVEL PACK (Filter Pack)

Material/Size 1/2 x 3/4 Volume/Weight Used 12000 lbs
Method of Installation Tremie
Depth: Placed FROM _____ ft. TO _____ ft.
GROUT
Material Bentonite Volume/Weight Used _____
Method of Installation Tremie
Depth: Placed FROM 25 ft. TO 0 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.		From	To
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.			
Brown Sand Clay		0	30
Brown Sand Clay small Gravel		30	52
Brown Sand Clay Gravel		52	70
Brown Sand Gravel		70	88
Rock		88	

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion _____ Total Depth of Well 88 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy