

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD


WELL LOG AND DRILLING REPORT
Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

1019693

WELL LOCATION

County Carroll Township MONROE
Owner/Builder TOM LALLON
(Circle One or Both) First Last
Address of Well Location 2014 Lakewood Dr
Number Street Name
City Shenandoah Zip Code +4 44675
Permit No. 34-2019 Section/Lot No. 11
(Circle One or Both)
Location of Well in State Plane coordinates, if available: Use of Well Residential
N ☐ X 944.00 +/- 10 ft. or m
S ☐ Y 944.00 +/- 10 ft. or m
Elevation of Well 944.00 +/- 10 ft. or m
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source My Elevation App
Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: N-40.54911 Long: W-81.2382



WELL TEST*

Pre-Pumping Static Level 19 ft. Date 9/19/17
Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other
☐ Air ☐ Bailing ☒ Pumping* ☐ Other
Test Rate 10.4 gpm Duration of Test 1/2 hrs.
Feet of Drawdown ? ft. Sustainable Yield 10.4 gpm
*(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No
Quality CLEAR ODORLESS

PUMP/PITLESS

Type of pump Submersible Capacity 10 gpm
Pump set at 85 ft. Pitless Type Pull thru
Pump installed by SEAN A Speedy

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm SEAN A Speedy Drilling LLC
Address 1057 Roswell Rd NW
City, State, Zip Carrollton Ohio

Signed Sean Speedy Date 10/13/17
ODH Registration Number 02550

CONSTRUCTION DETAILS

☐ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other ?
BOREHOLE/CASING (measured from ground surface)
1 ☐ Borehole Diameter 3 inches Depth ? ft.
Casing Diameter 5.0 in. Length ? ft. Thickness .250 in.
2 ☐ Borehole Diameter 5.0 inches Depth 93 ft.
Casing Diameter 5.0 in. Length ? ft. Thickness ? in.
Casing Height Above Ground 1.08 ft.
Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐
2 ☐ 2 ☐ 2 ☒ 2 ☐
Joints 1 ☐ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐
2 ☐ 2 ☐ 2 ☐ 2 ☐

SCREEN

Diameter ? Slot Size ? Screen Length ? ft.
Type ? Material ?
Set Between ? ft. and ? ft.

GRAVEL PACK (Filter Pack)

Material/Size ? Volume/Weight Used ?
Method of Installation ?
Depth: Placed FROM ? ft. TO ? ft.

GROUT

Material ? Volume/Weight Used ?
Method of Installation ?
Depth: Placed FROM ? ft. TO ? ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.		From	To
Extended casing on existing well.			
Steel casing original extended with dresser coupling AND plastic SDR 21			
No well log on file with DNR			

*(If more space is needed to complete drilling log, use next consecutively numbered form.)
Date of Well Completion 9/19/17 Total Depth of Well 93 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy