

WELL LOG AND DRILLING REPORT

1020069

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION		CONSTRUCTION DETAILS																
County <u>STARK</u> Township <u>LAURENCE</u> Owner/Builder (Circle One or Both) <u>Jim SHIPLETT</u> Address of Well Location <u>6896 AKRON AVE</u> City <u>CANAL FULTON</u> Zip Code +4 <u>44614</u> Permit No. <u>26316</u> Section/Lot No. (Circle One or Both) Location of Well in State Plane coordinates, if available: Use of Well <u>RESIDENTIAL</u> N ☐ X ☐ S ☐ Y ☐ Elevation of Well <u>1070</u> ft. or m Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source Source of Coordinates: ☒ GPS ☐ Survey ☐ Other		☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other BOREHOLE/CASING (measured from ground surface) 1 ☒ Borehole Diameter <u>5</u> inches Depth <u>130</u> ft. Casing Diameter <u>5.5</u> in. Length <u>60</u> ft. Thickness <u>1258</u> in. 2 ☐ Borehole Diameter _____ inches Depth _____ ft. Casing Diameter _____ in. Length _____ ft. Thickness _____ in. Casing Height Above Ground _____ ft. Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other 2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other SCREEN Diameter _____ Slot Size _____ Screen Length _____ ft. Type _____ Material _____ Set Between _____ ft. and _____ ft. GRAVEL PACK (Filter Pack) Material/Size _____ Volume/Weight Used _____ Method of Installation _____ Depth: Placed FROM _____ ft. TO _____ ft. GROUT Material <u>GRANULAR GROUT</u> Volume/Weight Used <u>250#</u> Method of Installation <u>DRY DRIVEN</u> Depth: Placed FROM <u>60</u> ft. TO <u>SURFACE</u> ft.																
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____ 		DRILLING LOG* INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc. <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th style="text-align: center;">From</th> <th style="text-align: center;">To</th> </tr> </thead> <tbody> <tr> <td>CLAY & GRAVEL</td> <td style="text-align: center;">0</td> <td style="text-align: center;">54</td> </tr> <tr> <td>BROWN SAND ROCK</td> <td style="text-align: center;">54</td> <td style="text-align: center;">73</td> </tr> <tr> <td>SHALE</td> <td style="text-align: center;">73</td> <td style="text-align: center;">130</td> </tr> <tr> <td colspan="3" style="text-align: center;">WATER AT 93'</td> </tr> </tbody> </table>			From	To	CLAY & GRAVEL	0	54	BROWN SAND ROCK	54	73	SHALE	73	130	WATER AT 93'		
	From	To																
CLAY & GRAVEL	0	54																
BROWN SAND ROCK	54	73																
SHALE	73	130																
WATER AT 93'																		
WELL TEST* Pre-Pumping Static Level <u>68</u> ft. Date <u>11-19-20</u> Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other ☐ Air ☒ Bailing ☐ Pumping* ☐ Other Test Rate <u>15</u> gpm Duration of Test <u>1</u> hrs. Feet of Drawdown <u>40</u> ft. Sustainable Yield <u>15</u> gpm *(Attach a copy of the pumping test record, per section 1521.05, ORC) Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No Quality <u>CLEAR</u>																		
PUMP/PITLESS Type of pump <u>SUBMERSIBLE</u> Capacity <u>10</u> gpm Pump set at <u>120</u> ft. Pitless Type <u>BAKER</u> Pump installed by <u>ROCK WELL DRILLING & PUMP CO. INC.</u> I hereby certify the information given is accurate and correct to the best of my knowledge. Drilling Firm <u>ROCK WELL DRILLING & PUMP CO. INC.</u> Address <u>5548 MANCHESTER RD.</u> City, State, Zip <u>AKRON OHIO 44319</u> Signed <u>H. J. Looney</u> Date <u>12/2/20</u> ODH Registration Number <u>173</u>																		

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy