

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources

Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

1020215

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOCATION

County miami Township _____

Owner/Builder Darrel Potter
(Circle One or Both) First Last

Address of Well Location 684 Ginghamburgs
Number Street Name

City T. P. City Zip Code +4

Permit No. 536368 Section/Lot No. _____
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Domestic

N ☐ X _____ +/- _____ ft. or m

S ☐ Y _____ +/- _____ ft. or m

Elevation of Well _____ +/- _____ ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other _____

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other _____

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5 1/2 inches Depth 81 ft.
Casing Diameter 6 1/2 in. Length 78 ft. Thickness 185 in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 18 1/2 ft.

Type 1 ☐ Steel 1 ☒ Galv. 1 ☐ PVC 1 ☐ Other _____
2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other _____

Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐ Other _____
2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other _____

SCREEN

Diameter 4 1/2 Slot Size #50 Screen Length 3 ft.

Type Machine Sintered Material PVC

Set Between 81 ft. and 78 ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO 65 lbs ft.

GROUT

Material Penseal Volume/Weight Used 65 lbs

Method of Installation Dry Driven

Depth: Placed FROM _____ ft. TO 81 ft.

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____

North

South

WELL TEST*

Pre-Pumping Static Level 12 ft. Date 11-12-18

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other _____

☐ Air ☒ Bailing ☒ Pumping* ☐ Other _____

Test Rate 16 gpm Duration of Test 1 hrs.

Feet of Drawdown 30 ft. Sustainable Yield 16 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality Clear

PUMP/PITLESS

Type of pump Sub Capacity 10 gpm

Pump set at 65 ft. Pitless Type W/H

Pump installed by Roger Adkins

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Adkins Well Drilling

Address 7795 W. Martin Rd

City, State, Zip Covington Ohio 45318

Signed Roger Adkins Date 11-12-18

ODH Registration Number 3296

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.		From	To
Top soil		0	2
Clay - Gravel		2	50
Sand gravel		50	52
clay - sand		52	70
Sand gravel		70	72
Clay		72	75
Sand gravel		75	81
water 78			

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 11-12-18 Total Depth of Well 81 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy