

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION

County Highland Township Concord

Owner/Builder Kristine Ritchie

Address of Well Location 1187 Dickey Rd.

City Hillsboro Oh Zip Code +4 45133

Permit No. 514475

Location of Well in State Plane coordinates, if available:

Use of Well

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

North

West

South

East

Hillsboro

Dickey Rd

Fairfax

St 247

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 6 5/8 inches Depth 84'-2" ft.

Casing Diameter 6 5/8 in. Length 84'-2" ft. Thickness .188 in.

2 ☐ Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐

2 ☐ 2 ☐ 2 ☐ 2 ☐ Other

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐

2 ☐ 2 ☐ 2 ☐ 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

From To

0-26 Brown clay 0' 26'

gray clay 26' 76'

gray shale 76' 125'

WELL TEST*

Pre-Pumping Static Level ft. Date

Measured from: ☐ Top of Casing ☐ Ground Level ☐ Other

☐ Air ☐ Bailing ☐ Pumping* ☐ Other

Test Rate dry hole gpm Duration of Test hrs.

Feet of Drawdown ft. Sustainable Yield gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No

Quality dry hole

PUMP/PITLESS

Type of pump Capacity gpm

Pump set at ft. Pitless Type

Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Vernon Gregory Well Drilling

Address 5274 Cape Rd

City, State, Zip Milington Oh 45177

Signed Vernon Gregory Date 11-18-21

ODH Registration Number 241

(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 11-18-21 Total Depth of Well 125 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B. COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy