

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION

County SUMMIT Township GREEN

Owner/Builder RYAN MACKEY

Address of Well Location 1811 DEANNA CNE

City NORTH CANTON Zip Code +4 44720

Permit No. 558557 Section/Lot No.

Location of Well in State Plane coordinates, if available: Use of Well RESIDENTIAL

N ☐ X ft. or m

S ☐ Y ft. or m

Elevation of Well 1190 ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

CONSTRUCTION DETAILS

☐ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5 inches Depth 130 ft.

Casing Diameter 5.5 in. Length 99 ft. Thickness .258 in.

2 ☐ Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground ft.

Type ☒ Steel ☐ Galv. ☐ PVC ☐ Other

2 ☐ ☐ ☐ ☐

Joints ☒ Threaded ☐ Welded ☐ Solvent ☐ Other

2 ☐ ☐ ☐ ☐

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material GRANULAR GROUT Volume/Weight Used 300#

Method of Installation DRY DRIVEN

Depth: Placed FROM 99 ft. TO SURFACE ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
BROWN CLAY & GRAVEL	0	26
GRAY CLAY & GRAVEL	26	80
SOFT SHALE	80	92
SHALE ROCK	92	105
GRAY SAND ROCK	105	116
BROWN SAND ROCK	116	118
GRAY SAND ROCK	118	130

WATER AT 120'

WELL TEST*

Pre-Pumping Static Level 50 ft. Date 10/9/20

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 15 gpm Duration of Test 1 hrs.

Feet of Drawdown 60 ft. Sustainable Yield 15 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality CLEAR

PUMP/PITLESS

Type of pump SUBMERSIBLE Capacity 10 gpm

Pump set at 120 ft. Pitless Type BAKER

Pump installed by PUGH WELL DRILLING

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm PUGH WELL DRILLING AND CO INC

Address 5546 MANCHESTER RD

City, State, Zip AKRON OH 44319

Signed H. L. Looney Date 10/9/20

ODH Registration Number 173

(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 10/9/20 Total Depth of Well 130 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy