

WELL LOG AND DRILLING REPORT

OHIO DEPARTMENT OF NATURAL RESOURCES

1021978

Division of Water, 1939 Fountain Square Drive

Columbus, Ohio 43224-9971 Voice: (614) 265-6739 Fax: (614) 265-6767

WELL LOCATION		CONSTRUCTION DETAILS																			
County: FULTON Township: FRANKLIN Owner/Builder: Tyler Bernath Well Location: COUNTY ROAD H City: WAUSEON Zip +4: 43567 Permit #: 2020063 Section: 1 Lot: Location in State Plane Use of well: DOMESTIC X +/- Feet Y +/- Feet Elevation of Well: +/- Feet Datum Plain: Elevation Source: Source of Coordinates:		Drilling Method: Rotary BORE HOLE/CASING (Measured from ground surface) 1 Borehole Diameter: 8.00 Inches Depth: 146.00 Feet Casing Diameter: 5.00 Inches Length: 141 Ft Thickness: 0.265 In 2 Borehole Diameter: Inches Depth: Feet Casing Diameter: Inches Length: Ft Thickness: In Casing Height above Ground: 1 Feet Type 1 PVC plastic 2 Joints 1 Solvent welded 2 SCREEN Diameter: 6 In Slot size: 15 Length: 5 Ft. Type & Material: Stainless steel-wire Set between: 146 Ft. an 141 Ft. GRAVEL PACK Material/Size: #0 Sand Volume/Weight Used 200.00 Pounds Method of Installation: Gravity Pour Depth: Placed From 146 Feet To: 135 Feet GROUT Material: Bentonite slurry #Volume/Weight Used: 450 Pounds <i>180 gal of water</i> Method of installation: Grout pipe outside casing Depth: Placed From 135 Feet To: 0 Feet																			
Map Sketch Latitude: 41.58765 Longitude: -84.24422																					
WELL TEST*		DRILLING LOG																			
Pre-pumping Static Level: 35 ft Date 4/8/2021 Measured from: Ground Level Test Method: Air Test Rate: 40 gpm Duration of Test: 2 hrs Ft of Drawdown: 2 Feet Sustainable Yield: gpm Attach a copy of the pumping test record, per section 1521.05, ORC Is Copy Attached?: No Flowing Well: No Water Quality: FRESH & CLEAR		<table><thead><tr><th></th><th>From</th><th>To</th></tr></thead><tbody><tr><td>Topsoil</td><td>0</td><td>2</td></tr><tr><td>Yellow Clay</td><td>2</td><td>16</td></tr><tr><td>Gray Clay</td><td>16</td><td>88</td></tr><tr><td>Gray Clay & Gravel</td><td>88</td><td>140</td></tr><tr><td>Sand & Gravel + broken shale</td><td>140</td><td>146</td></tr></tbody></table>			From	To	Topsoil	0	2	Yellow Clay	2	16	Gray Clay	16	88	Gray Clay & Gravel	88	140	Sand & Gravel + broken shale	140	146
	From	To																			
Topsoil	0	2																			
Yellow Clay	2	16																			
Gray Clay	16	88																			
Gray Clay & Gravel	88	140																			
Sand & Gravel + broken shale	140	146																			
PUMP/PITLESS <i>Pump system to be installed at a later date.</i>																					
I hereby certify the information given is accurate and correct to the best of my knowledge. Drilling Firm: Watson Well Drilling, Inc. Address: 13580 County Road C City, State, Zip: Bryan, OH 43506 Signed <i>James N. Watson</i> Date <i>5-4-21</i> Registered Representative ODH Registration Number: 823		Date of Well Completion: 4/8/2021 Total Depth of Well: 146 Feet																			

Completion of this form is required by section 1521.05, Ohio Revised Code - File within 30 days after completion of drilling.

ORIGINAL COPY TO ODNR, Division of Water, 1939 Fountain Square Drive, Columbus, OHIO 43224-9971

Submit copies to Customer, Local Health Department, Company