

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

1022203

County Trumbull Township Hubbard

Owner/Builder THOMAS WOSKOWSKI

Address of Well Location 5829106. Hubbard, Rd


City Hubbard Zip Code +4 4425

Permit No. 612427

Location of Well in State Plane coordinates, if available:

Use of Well DOMESTIC

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____



☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

☐ Borehole Diameter 6 7/8 inches

Casing Diameter 6 7/8 in. Length 27 ft. Thickness .188 in.

☐ Borehole Diameter _____ inches

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 2'

Type

☒ Steel ☐ Galv. ☐ PVC ☐ Other

☐ 2 ☐ Steel ☐ 2 ☐ Galv. ☐ 2 ☐ Other

☐ Joints ☐ Threaded ☒ Welded ☐ Solvent ☐ Other

☐ 2 ☐ Threaded ☐ 2 ☐ Welded ☐ 2 ☐ Solvent ☐ 2 ☐ Other

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material BENTONITE Volume/Weight Used 300 Lbs.

Method of Installation GRAVITY

Depth: Placed FROM 27' ft. TO SURFACE ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>Hd. GRAY SHALE</u>	<u>0</u>	<u>34</u>
<u>GRAY SANDSTONE H2O</u>	<u>34</u>	<u>60</u>
<u>GRAY SHALE</u>	<u>60</u>	<u>86</u>
<u>WHITE SANDSTONE H2O</u>	<u>86</u>	<u>96</u>

Pre-Pumping Static Level 18 ft. Date 1-24-24

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 10 gpm Duration of Test 2 hrs.

Feet of Drawdown 70 ft. Sustainable Yield 10 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality Clear

PUMP/PITLESS

Type of pump Submersible Capacity 12 gpm

Pump set at 90 ft. Pitless Type DICKENS, PULL THROUGH

Pump installed by E.R. Eppinger

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm E.R. EPPINGER Well Drilling

Address Box 365

City, State, Zip New Bedford, Pa. 16140

Signed E.R. Eppinger Date 2-5-24

ODH Registration Number 000 734

Date of Well Completion 1-24-24 Total Depth of Well 96 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy