


WELL LOG AND DRILLING REPORT

1022475

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION	CONSTRUCTION DETAILS															
County <u>Knott</u> Township <u>Pike</u> Owner/Builder <u>Thomas Bailey</u> Address of Well Location <u>20365 Crooked Rd</u> City <u>Butler 44822</u> Zip Code +4 <u>44822</u> Permit No. <u>2025-002</u> Section/Lot No. <u></u> Location of Well in State Plane coordinates, if available: <u>Home</u> N ☐ X <u></u> +/- <u></u> ft. or m S ☐ Y <u></u> +/- <u></u> ft. or m Elevation of Well <u>1140</u> +/- <u></u> ft. or m Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source <u>1140-GPS</u> Source of Coordinates: ☒ GPS ☐ Survey ☐ Other	☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other BOREHOLE/CASING (measured from ground surface) 1 Borehole Diameter <u>5</u> inches Depth <u>178</u> ft. Casing Diameter <u>5 1/2</u> in. Length <u>66</u> ft. Thickness <u>.237</u> in. 2 Borehole Diameter <u></u> inches Depth <u></u> ft. Casing Diameter <u></u> in. Length <u></u> ft. Thickness <u></u> in. Casing Height Above Ground <u>18 in</u> ft. Type ☒ Steel ☐ Galv. ☐ PVC ☐ Other Joints ☒ Threaded ☐ Welded ☐ Solvent ☐ Other SCREEN Diameter <u></u> Slot Size <u></u> Screen Length <u></u> ft. Type <u></u> Material <u></u> Set Between <u></u> ft. and <u></u> ft. GRAVEL PACK (Filter Pack) Material/Size <u></u> Volume/Weight Used <u></u> Method of Installation <u></u> Depth: Placed FROM <u></u> ft. TO <u></u> ft. GROUT Material <u>Bentonite</u> Volume/Weight Used <u>300#</u> Method of Installation <u>added 95 Driven</u> Depth: Placed FROM <u>66</u> ft. TO <u>0</u> ft.															
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: <u>40° 36' 41" N</u> Long: <u>82° 36' 11" W</u> 	DRILLING LOG* INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc. <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>Topsoil</td> <td>0</td> <td>1</td> </tr> <tr> <td>Brown clay, gravel mix</td> <td>1</td> <td>62</td> </tr> <tr> <td>Brown sand stone</td> <td>62</td> <td>175</td> </tr> <tr> <td>Gray</td> <td>175</td> <td>178</td> </tr> </tbody> </table>		From	To	Topsoil	0	1	Brown clay, gravel mix	1	62	Brown sand stone	62	175	Gray	175	178
	From	To														
Topsoil	0	1														
Brown clay, gravel mix	1	62														
Brown sand stone	62	175														
Gray	175	178														
WELL TEST* Pre-Pumping Static Level <u>72</u> ft. Date <u>9-10-25</u> Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other ☐ Air ☐ Bailing ☒ Pumping* ☐ Other Test Rate <u>12</u> gpm Duration of Test <u>4</u> hrs. Feet of Drawdown <u>12</u> ft. Sustainable Yield <u>12</u> gpm *(Attach a copy of the pumping test record, per section 1521.05, ORC) Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No Quality <u>CLEAR</u>	WATER - 90-160' 15 gpm															
PUMP/PITLESS Type of pump <u>Submersible</u> Capacity <u>10</u> gpm Pump set at <u>145</u> ft. Pitless Type <u>CLEAR WAY</u> Pump installed by <u>Driller</u> I hereby certify the information given is accurate and correct to the best of my knowledge. Drilling Firm <u>Tedrow Waterwell Drilling LLC</u> Address <u>16560 Wooster Rd</u> City, State, Zip <u>Mt. Vernon Ohio 43058</u> Signed <u>David Tedrow</u> Date <u>9-10-25</u> ODH Registration Number <u>01194</u>	*(If more space is needed to complete drilling log, use next consecutively numbered form.) Date of Well Completion <u>9-10-25</u> Total Depth of Well <u>178</u> ft.															

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy