

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD


WELL LOG AND LOGGING REPORT
Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

1022513

WELL LOCATION

County Lucas Township Lawrence
Owner/Builder CHRISTINE/THOMAS SNETLER
(Circle One or Both) First Last
Address of Well Location 9689 ST. PETERS CH. RD. N.W.
Number Street Name
City BOLIVAR OH Zip Code +4 44612
Permit No. 631214 Section/Lot No. (Circle One or Both)
Location of Well in State Plane coordinates, if available: Use of Well BARN/S.F.P.
N ☐ X 40' 36 +/- 289 ft. or m
S ☐ Y 081' 29 +/- 391 ft. or m
Elevation of Well 1125 ft. or m
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source
Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____
North

**WELL TEST***

Pre-Pumping Static Level 295 ft. Date 06-17-2026
Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other
☒ Air ☐ Bailing ☐ Pumping* ☐ Other
Test Rate 15 gpm Duration of Test 15 hrs.
Feet of Drawdown 45 ft. Sustainable Yield 15 gpm
(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No
Quality 7 GPH 7 PH 0.5 PPM

PUMP/PITLESS

Type of pump SUB Capacity 10 gpm
Pump set at 386 ft. Pitless Type BRASS-FREE
Pump installed by GRIFFITH DRILLING
I hereby certify the information given is accurate and correct to the best of my knowledge.
Drilling Firm GRIFFITH DRILLING
Address 1899 ZUTAVEN CH. RD NW
City, State, Zip BOLIVAR OH 44612

Signed Dennis Griffith Date 07-02-2026
ODH Registration Number 02082

CONSTRUCTION DETAILS

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other
BOREHOLE/CASING (measured from ground surface)
1 ☐ Borehole Diameter 8 1/2 inches Depth 349 ft.
Casing Diameter 5 in. Length 160' Thickness SRP/SDR
2 ☐ Borehole Diameter 5 inches Depth 90 ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.
Casing Height Above Ground 2 ft.
Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐
2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other
Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐
2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other
SCREEN
Diameter _____ Slot Size _____ Screen Length _____ ft.
Type _____ Material _____
Set Between _____ ft. and _____ ft.
GRAVEL PACK (Filter Pack)
Material/Size _____ Volume/Weight Used _____
Method of Installation _____
Depth: Placed FROM _____ ft. TO _____ ft.
GROUT
Material Benseal Volume/Weight Used 1.000 LBS
Method of Installation Pump
Depth: Placed FROM 349 ft. TO 0 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.		From	To
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.			
Clay		0	7
Sandy shale		7	26
Shale		26	62
Limestone		62	63
Coal & clay		63	77
Sandrock		77	169
Gray shale		169	181
Sandrock		181	233
Dark shale		233	241
Coal & clay		241	251
Limestone Dark shale		251	307
Limestone		307	309
Coal & clay		309	313
Dark shale		313	389
Sandy shale		389	428
Sandrock		428	442

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 06-19-2026 Total Depth of Well 442 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy