

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION

County Noble Township Morion

Owner/Builder Glen Hague
(Circle One or Both) First Last

Address of Well Location 52060 Gladys Rd
Number Street Name

City Summerfield OH Zip Code +4 43788

Permit No. WS2025.06 Section/Lot No.
(Circle One or Both)

Location of Well in State Plane coordinates, if available:
N ☐ X +/- ft. or m
S ☐ Y +/- ft. or m
Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 39.55942 Long: -81.348937
North

South

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 9 3/8 inches Depth 78 ft.
Casing Diameter 5 in. Length 80 ft. Thickness SOR 21 in.

2 ☐ Borehole Diameter inches Depth ft.
Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐
2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐
2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter 5 Slot Size .05 Screen Length ft.

Type Slotted Material PVC

Set Between 26 ft. and 80 ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Bentonite Volume/Weight Used 700#

Method of Installation Dry Pour

Depth: Placed FROM 25 ft. TO 25 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown clay	0	15
Gray clay	15	24
Gray sandstone	24	26
Gray shale	26	80
water encountered	38'	55

East

West

WELL TEST*

Pre-Pumping Static Level 23 ft. Date 10-24-25

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

☐ Air ☐ Bailing ☐ Pumping* ☐ Other

Test Rate 6 gpm Duration of Test 4 hrs.

Feet of Drawdown 80 ft. Sustainable Yield 6 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality

PUMP/PITLESS

Type of pump Capacity gpm

Pump set at ft. Pitless Type

Pump installed by

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm T.C. EXCAVATING & water well Drilling

Address 68771 Hopewell Rd

City, State, Zip Cambridge Ohio 43725

Signed Paul Vincent Date 10-24-25

ODH Registration Number 2797

(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 10-24-25 Total Depth of Well 80 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy