

WELL LOG AND DRILLING REPORT

1023679

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION

CONSTRUCTION DETAILS

County Muskingum Township Russell

Owner/Builder STEPHEN BRANDUR
(Circle One or Both) First Last

Address of Well Location 8652 PORTER RUN ROAD
Number Street Name

City RUSSVILLE OH Zip Code +4 43777

Permit No. 620912 Section/Lot No.
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well FAMILY

N ☐ X +/- ft. or m

S ☐ Y +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 39.83065 N Long: 82.15910 W

Lat 39.83065 N Long 82.15910 W

West

Porter Run Road

CRAP/R

Well

South

WELL TEST*

Pre-Pumping Static Level 30 ft. Date

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 10 gpm Duration of Test 42 hrs.

Feet of Drawdown 100 ft. Sustainable Yield 42 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☐ No

Quality CLEAR

PUMP/PITLESS

Type of pump SUBMERSIBLE Capacity 10 gpm

Pump set at 90 ft. Pitless Type PULL THROUGH

Pump installed by REP BURL

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm REP BURL

Address 8177 IMPERIAL NAT RD

City, State, Zip RUSSVILLE OHIO 43701

Signed REP BURL Date 9-14-25

ODH Registration Number 01592

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 10 inches Depth 27 ft.

Casing Diameter 6 in. Length 27 ft. Thickness 1/2 in.

2 ☒ Borehole Diameter 6 1/2 inches Depth 100 ft.

Casing Diameter 4 1/2 in. Length 80 ft. Thickness 1/2 in.

Casing Height Above Ground 1 FT

Type 1 ☐ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material PORTLAND CEMENT Volume/Weight Used 500 #

Method of Installation POURED IN

Depth: Placed FROM 0 ft. TO 27 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Top soil BROWN 0 3

SHALE BROWN 3 30

SHALE GRAY 30 40

SANDSTONE BROWN 40 45

SHALE GRAY 45 100

WATER AT 40 FT

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy