

WELL LOG AND DRILLING REPORT

1023680

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION

County PERRY Township MT PERRY

Owner/Builder Edith TROYER
(Circle One or Both) First Last

Address of Well Location 9600 TWP RD 51
Number Street Name

City MT. PERRY Zip Code 44601

Permit No. 2025037 Section/Lot No.
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well FAMILY DWELLING

N ☐ X +/- ft. or m

S ☐ Y +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 40.25034 North Long: 83.0018

SR. 22
TWP RD 51
HOUSE
WELL

West

East

South

WELL TEST*

Pre-Pumping Static Level 70 ft. Date 10-14-2023

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 8 gpm Duration of Test 2 hrs.

Feet of Drawdown 150 ft. Sustainable Yield gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality GOOD

PUMP/PITLESS

Type of pump SUBMERSIBLE Capacity 10 gpm

Pump set at 140 ft. Pitless Type PULL THROUGH

Pump installed by ROGER GARD

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm ROGER GARD WELL DRILLING

Address 8177 Hopewell Rd

City, State, Zip ZANESVILLE OHIO 43700

Signed Roy Gard Date 5-14-2025

ODH Registration Number 1WS 26-30

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☒ Borehole Diameter 6 inches Depth 40 ft.

Casing Diameter 6 in. Length 40 ft. Thickness 1/2 in.

2 ☒ Borehole Diameter 6 inches Depth 150 ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground 170 ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material PORTLAND CEMENT Volume/Weight Used 600#

Method of Installation PACKING

Depth: Placed FROM 0 ft. TO 40 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top soil BROWN	0	5
SHALE BROWN	5	20
SHALE GRAY	20	45
CLAY GRAY	45	65
SANDSTONE GRAY	65	90
SAND & SHALE GRAY	90	150

WATER AT 75 FT.

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 10-14-2023 Total Depth of Well 150 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy