

WELL LOG AND DRILLING REPORT

1023721

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION

County Licking Township Perry

Owner/Builder (Circle One or Both) Kyle Stevens
First Last

Address of Well Location 7070 Pleasant Valley Rd.
Number Street Name

City FRAZEEHURST Zip Code +4 43820

Permit No. 2024 2040 Section/Lot No. (Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Family Dwelling

N ☐ X 950' +/- 950' ft. or m


S ☐ Y 950' +/- 950' ft. or m

Elevation of Well 950' +/- 950' ft. or m

Datum Plain: ☒ NAD27 ☐ NAD83 Elevation Source GPS

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 40 09 309 082.12.923 Long: 82 12 923



WELL TEST*

Pre-Pumping Static Level 150 ft. Date 10-17-2024

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

☒ Air ☐ Bailing ☐ Pumping* ☐ Other

Test Rate 30 gpm Duration of Test 1 hrs.

Feet of Drawdown 0 ft. Sustainable Yield 15 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☒ Yes ☐ No

Quality Clear

PUMP/PITLESS

Type of pump Submersible Capacity 10 gpm

Pump set at 245 ft. Pitless Type Pull Through

Pump installed by Steve Netters

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Steven W. Netters Drilling

Address 10525 Wilkins Run Rd

City, State, Zip Newark Ohio 43055

Signed SW Netters Date 10-17-2024

ODH Registration Number 969

CONSTRUCTION DETAILS

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☒ Borehole Diameter 9 inches Depth 152 ft.

Casing Diameter 6.625 in. Length 152 ft. Thickness SDR 21 in.

2 ☒ Borehole Diameter 6 inches Depth 260 ft.

Casing Diameter 6 in. Length 18" ft. Thickness 18" in.

Casing Height Above Ground 18" ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐ Other

2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐ Other

2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other

SCREEN N.A.

Diameter N.A. Slot Size N.A. Screen Length N.A. ft.

Type N.A. Material N.A.

Set Between N.A. ft. and N.A. ft.

GRAVEL PACK (Filter Pack) N.A.

Material/Size N.A. Volume/Weight Used N.A.

Method of Installation N.A.

Depth: Placed FROM N.A. ft. TO N.A. ft.

GROUT 240 gallons 500lbs

Material BEUSEAL-EZ MUD Volume/Weight Used 240 gallons 500lbs

Method of Installation grout Pump

Depth: Placed FROM 152 ft. TO Surface ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED. Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.		From	To
Brown Sandstone		0	55
Gray Shale		55	80
Brown Sandstone		80	125
Yellow Sandstone		125	165
Gray Sandstone		165	215
INJUN Sandstone		215	260
5 gpm Water At 215'			
30 gpm Water At 260'			

(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 10-17-2024 Total Depth of Well 260 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy