


TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

1023723

WELL LOCATION

County Wicking Township MARY ANNOwner/Builder
(Circle One or Both)RICHARD BARRETTAddress of
Well Location13107 Jobs Rd. N.ECity NEWARK Zip Code +4 43055Permit No. 2025003Section/Lot No.
(Circle One or Both)Location of Well in State Plane
coordinates, if available:Use of Well SINGLE-FAMILYN ☐ X 902' +/- 902' ft. or mS ☐ Y 902' +/- 902' ft. or mElevation of Well 902' +/- 902' ft. or mDatum Plain: ☒ NAD27 ☐ NAD83 Elevation Source GPSSource of Coordinates: ☒ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street
intersections, county roads, buildings or other notable landmarks. If latitude and
longitude are available please include here: Lat: 40-07 656 088 18 128 Long: 81-18 128

WELL TEST*

Pre-Pumping Static Level 35 ft. Date 7-22-2025Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other☐ Air ☒ Bailing ☐ Pumping* ☐ OtherTest Rate 15 gpm Duration of Test 1 hrs.Feet of Drawdown 10 ft. Sustainable Yield 10 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ NoQuality CLEAR

PUMP/PITLESS

Type of pump Submersible Capacity 10 gpmPump set at 75 ft. Pitless Type Pull ThroughPump installed by STEVE NETHERS

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm STEVEN W. NETHERS DRILLINGAddress 10525 WILLIAMS RUN RDCity, State, Zip NEWARK OHIO 43055Signed Steve Nethers Date 7-28-25ODH Registration Number 969

CONSTRUCTION DETAILS

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

☒ Borehole Diameter 8" inches Depth 44 ft.Casing Diameter 5.563 in. Length 1/4 in. Thickness 1/4 in.☒ Borehole Diameter 5" inches Depth 85 ft.Casing Diameter 5" in. Length 18" ft. Thickness 1/4 in.Casing Height Above Ground 18" ft.Type ☒ 1 Steel ☐ 2 Galv. ☐ 1 PVC ☐ 2 OtherJoints ☒ 1 Threaded ☐ 2 Welded ☐ 1 Solvent ☐ 2 OtherSCREEN N.A.Diameter N.A. Slot Size N.A. Screen Length N.A. ft.Type N.A. Material N.A.Set Between N.A. ft. and N.A. ft.GRAVEL PACK (Filter Pack) N.A.Material/Size N.A. Volume/Weight Used N.A.Method of Installation N.A.Depth: Placed FROM N.A. ft. TO N.A. ft.

GROUT

Material BENZON-EZ MUD Volume/Weight Used 72 gallon / 150 lbsMethod of Installation GROUT PUMP TRENCH TUBEDepth: Placed FROM 44 ft. TO SURFACE ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Shale	0	20
Gray Clay - HARD	20	44
White Sandstone	44	85

Water at 50'

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 7-28-25 Total Depth of Well 85 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy