

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT


Ohio Department of Natural Resources
Division of Soil and Water Resources, 2045 Morse Road Building B
Columbus, Ohio 43229-6693 Voice (614) 265-6740 Fax (614) 265-6767

1023778

WELL LOCATION

County Medina Township Sharon
Owner/Builder Modern Home Concepts
(Circle One or Both) First Last
Address of Well Location 1597 Beacon Hill
City Wadsworth Zip Code +4 44281
Permit No. 542822 Section/Lot No. 845
(Circle One or Both)
Location of Well in State Plane coordinates, if available: Use of Well house
N ☐ X 41° 04' 58" +/- ft. or m
S ☐ Y 081° 44' 27" +/- ft. or m
Elevation of Well 1114 +/- ft. or m
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source GPS
Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____



WELL TEST*

Pre-Pumping Static Level 54 ft. Date 1-18-79
Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other
☒ Air ☐ Bailing ☐ Pumping* ☐ Other
Test Rate 10 gpm Duration of Test 1/2 hrs.
Feet of Drawdown 40 ft. Sustainable Yield 10 gpm
(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☒ Yes ☒ No Flowing Well? ☐ Yes ☒ No
Quality clear / hard

PUMP/PITLESS

Type of pump sub Capacity 10 gpm
Pump set at 110 ft. Pitless Type LD 510
Pump installed by Don
I hereby certify the information given is accurate and correct to the best of my knowledge.
Drilling Firm Donny Daulton
Address 3459 Orange
City, State, Zip Medina OH 44130
Signed Funk Date 1-9-20
ODH Registration Number 384

CONSTRUCTION DETAILS

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other
BOREHOLE/CASING (measured from ground surface)
1 ☒ Borehole Diameter 4 1/2 inches Depth 59 ft.
Casing Diameter 5 1/2 in. Length 60 ft. Thickness 5DR21 in.
2 ☐ Borehole Diameter 4 1/4 inches Depth 59-120 ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.
Casing Height Above Ground 12 ft.
Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐ Other
2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other
Joints 1 ☐ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other
2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other cut off
SCREEN
Diameter _____ Slot Size _____ Screen Length _____ ft.
Type _____ Material _____
Set Between _____ ft. and _____ ft.
GRAVEL PACK (Filter Pack)
Material/Size _____ Volume/Weight Used _____
Method of Installation _____
Depth: Placed FROM _____ ft. TO _____ ft.
GROUT
Material benzol Volume/Weight Used 120 gal / 250
Method of Installation pressure grout
Depth: Placed FROM 59 ft. TO grade ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.		From		To
Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.				
<u>brown sandy clay</u>		<u>0</u>		<u>20</u>
<u>brown sandstone</u>		<u>20</u>		<u>40</u>
<u>grey shale</u>		<u>40</u>		<u>50</u>
<u>grey sandstone</u>		<u>50</u>		<u>81</u>
<u>light grey sandstone</u>		<u>81</u>		<u>120</u>
<u>water 108 + 81</u>				

(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 1-9-20 Total Depth of Well 120 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF SOIL AND WATER RESOURCES, 2045 MORSE ROAD BLD. B, COLS., OHIO 43229-6693

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy