

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

N^o 119506

County Muskegon Township Falls Section of Township
or Lot Number

Owner Mr. Edul James Address off Rte. 77 N. of Janesville

Location of property Puckey Road Janesville

CONSTRUCTION DETAILS

Casing diameter 5' Length of casing 28'
Type of screen Length of screen
Type of pump Installed by
Capacity of pump
Depth of pump setting others

PUMPING TEST


Pumping rate 15 G.P.M. Duration of test 10 hrs.
Drawdown 4 ft. Date March 10-54
Developed capacity 15 G.P.M.
Static level—depth to water 16 ft.
Pump installed by others

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	12 Ft.
<u>Top Soil</u>		
<u>Met mud - gravel</u>	<u>12'</u>	<u>24'</u>
<u>drift</u>		
<u>Gray Shale</u>	<u>24'</u>	<u>36'</u>
<u>Gray Sand Rock</u>	<u>36'</u>	<u>50'</u>
<u>Water at 46'</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm M. J. Dutton

Address 144 1/2 S. 6th St.

Janesville, O

Date March 10-1954

Signed M. J. Dutton

(227)