

WELL LOG AND DRILLING REPORT

ORIGINAL

LOCATED

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

(172-34

No 119517

County Muskingum Township Washington Section of Township 449 or Lot Number Brighton Blvd.
Owner Mr. Bernard Dausen Address 449 Brighton Blvd.
Location of property (4 mi north of Zanesville City Limits) Zanesville
on Route 666

CONSTRUCTION DETAILS

PUMPING TEST

Casing diameter 5" Length of casing 35'
Type of screen Drilled Length of screen 5'
Type of pump Installed by others
Capacity of pump 1000 G.P.M.
Depth of pump setting 15'

Pumping rate 1000 G.P.M. Duration of test 1 hrs.
Drawdown 3 ft. Date May 23-55
Developed capacity 1000 G.P.M.
Static level—depth to water 15' ft.
Pump installed by

WELL LOG

SKETCH SHOWING LOCATION

Formations
Sandstone, shale, limestone,
gravel and clay

From

To

0 Feet

12 Ft.

Top Soil 1
Sand
Blue shale

12

34


34

35

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

W.

E.



S.
See reverse side for instructions

Drilling Firm

Date

Address

Signed

M. L. Dutro
144125 6th St
Zanesville, Ohio 1-5

May 23-55
M. L. Dutro

LOCATED