

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

No 125587

County Maioning Township CANFIELD Cornettsburg Section of Township or Lot Number _____
Owner Mr John Snyder Address Cornettsburg
Location of property 1/2 mile west of Cornettsburg on Rt 62

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 35'
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____

PUMPING TEST

Pumping rate 20 G.P.M. Duration of test _____ hrs.
Drawdown None ft. Date 3-26-55
Developed capacity _____
Static level—depth to water 10' ft.
Pump installed by _____


WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
Clay	0 Feet	20' Ft.
Clay and Gravel	20	34
Sandstone	34	50'
Shale	50	65'

Water at
50' and 60'

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



S.
See reverse side for instructions

Drilling Firm Walsh Pump and Supply Date 3-26-55
Address 126 N. Glenallen Signed Robert F. Walsh
Youngstown O