

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

No 141205

County Butler Co Township Wayne Section of Township 23
or Lot Number
Owner Stark Address 59.10 Wayne Trac Rd
Location of property Wayne Trac Road & Ford Road

CONSTRUCTION DETAILS

Casing diameter 6 1/2 Length of casing 22
Type of screen none Length of screen none
Type of pump —
Capacity of pump —
Depth of pump setting —

PUMPING TEST


Pumping rate 120 G.P.M. Duration of test 1 hour
Drawdown 15 ft. Date 10-6-57
Developed capacity 120 gpm
Static level—depth to water 10 feet ft.
Pump installed by —

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	Ft.
<u>clay</u>	<u>10</u>	
<u>shale</u>	<u>11</u>	
<u>stone</u>	<u>28</u>	<u>ft</u>
<u>water</u>		
<u>stone</u>		
<u>stone</u>		
<u>stone</u>	<u>45</u>	<u>feet</u>
<u>stone</u>		<u>W.</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm North Hamilton Ohio Date 10-6-57
Address 1944 - Williams St Signed for Pipe