

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Columbus, Ohio

No 142096

County Montgomery Township Cardolph Section of Township 23
or Lot Number 23
Owner Dr E. L. Loomis Address R.R. 1 Clayton
Location of property St route 49

CONSTRUCTION DETAILS

Casing diameter 4 1/2 Length of casing 43
Type of screen — Length of screen —
Type of pump —
Capacity of pump —
Depth of pump setting —

PUMPING TEST

Pumping rate 10 G.P.M. Duration of test 9 hrs
Drawdown 1 ft. Date 5-11-56
Developed capacity 600 gal/hr
Static level—depth to water 37 ft
Pump installed by Billisner

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	0.6 Ft.
<u>dry</u>		
<u>sand</u>	<u>36</u>	<u>40</u>
<u>gravel</u>	<u>40</u>	<u>43</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.
W.
S.
E.
old habund
St R 49

See reverse side for instructions

Drilling Firm

Address

Date

Signed

J. Albers
Clayton Ohio

12-23-56
Julius J. Albers

161